



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name Vineyard Park at South Hill
Address 3319 57TH ,
City, State, Zip Spokane, WA

Provider Number 2562
Approval Status Approved
Facility Type Residential Care

On 07/31/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

1 Admin Complaint

COMPLAINT # 187472

Here's a complaint of Fire alarm

Please include the answers to the following questions in your report in FDM.

1. The cause of the fire? N/A
2. If the sprinklers were activated? No
3. If there was an evacuation / how many were evacuated? 1
4. If there were injuries / how many? No
5. Did the fire department respond? Yes

Complaint ref # 187472

At 1600 on the July 31, 2025, I entered The Vineyard Park at South Hill in regard to a complaint about fire alarm activation. I interviewed Executive Director Aleshia Salter and Maintenance Director Cryss Bazan.

The fire alarm activated when a smoke detector in resident room 217 shorted due to water damage from the room above, kitchen sink overflowed due to water not being turned off.

Facility was put into fire watch by fire department until fire alarm contractor removed and replaced the detector.


All staff responded in alignment with their policies and procedures.

No violations cited.


Next inspection scheduled on or after:

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative


Signature

Deputy State Fire Marshal Barbara McMullen
6403 W ROWAND DR
Spokane WA 99219
(509) 954-2746


Signature

 Maintenance
Director
Print Name and Title