



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Vineyard Park at South Hill	Provider Number	2749
Address	3319 57TH ,	Approval Status	Approved
City, State, Zip	Spokane, WA	Facility Type	Residential Care

On 12/17/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

1 Admin Complaint

COMPLAINT # 202519

Here's a complaint of Fire Alarm trouble.

Please include the answers to the following questions in your report in FDM.

1. The cause of the fire?
2. If the sprinklers were activated?
3. If there was an evacuation / how many were evacuated?
4. If there were injuries / how many?
5. Did the fire department respond? Yes, No

On December 17, 2025 a representative from the State Fire Marshals Office contacted the Executive Director and Maintenance Director regarding complaint 202519.

The fire alarm system reported a trouble with a faulty module. Facility contacted Performance System Integrated (PSI), fire alarm contractor, to perform diagnostics and testing to find the issue. PSI found the issue and repaired the faulty module and other items. The Fire Alarm system is back in normal condition.

Facility followed procedures with regards to implementing a fire watch. Facility Executive Director also provided in-service training to staff on fire watch and fire safety.

No violations found.

Next inspection scheduled on or after:

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Signature

Ale Shi x Kelter EXECUTIVE DIRECTOR
Print Name and Title

Deputy State Fire Marshal Barbara McMullen
6403 W ROWAND DR
Spokane WA 99219
(509) 954-2746

Signature