



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Belle Vie of Allyn LLC	Provider Number	2757
Address	180 E WHEELRIGHT RD ,	Approval Status	Approved
City, State, Zip	Allyn, WA	Facility Type	Residential Care

On 03/16/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

1 Admin Complaint

COMPLAINT # 216128

Here's a complaint of Fire Doors

Please include the answers to the following questions in your report in FDM.

1. The cause of the fire?
2. If the sprinklers were activated?
3. If there was an evacuation / how many were evacuated?
4. If there were injuries / how many?
5. Did the fire department respond? Yes, No

COMPLAINT # 216128

On 3/16/2026 a complaint investigation was conducted at Belle Vie of Allyn LLC located at 180 East Wheelwright Street South, Allyn, WA 98524. The facility has a fire sprinkler system, and a fire alarm system to include pull stations, horns and strobes.

An interview was conducted with facility staff. During the inspection there were no doors propped open and the kitchen suppression system had been inspected.

There was no sign of a fire, the sprinkler system was not activated, there were no evacuations, there were no injuries, and the fire department did not respond.

Next inspection scheduled on or after:

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Signature

Print Name and Title Richard Manquira Director of Operations

Deputy State Fire Marshal Raul Murcia
PO BOX 42642
Olympia WA 98504
(360) 819-0067

Signature