




Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Birchview Memory Care Community	Provider Number	2760
Address	925 DUNLOP AVE ,	Approval Status	Approved
City, State, Zip	Sedro-Woolley, WA	Facility Type	Residential Care

On 01/22/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

All violations noted during previous related inspection(s) have been corrected.

Owner or Owner's Representative


Signature

MIKE BATZ MAIN DIR.
Print Name and Title

Deputy State Fire Marshal Brandon G. Brown
MP 235 SB Interstate 5
Bow WA 98232
(360) 791-7037


Signature

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Birchview Memory Care Community	Provider Number	2760
Address	925 DUNLOP AVE ,	Approval Status	Disapproved
City, State, Zip	Sedro-Woolley, WA	Facility Type	Residential Care

On 12/22/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

1 Power Supply

Portable, electric space heaters shall be plugged directly into an approved receptacle. (IFC 603.9.2, 2021)	The portable electric heater in the Marketing office is plugged into a power strip
--	--

2 Appliance Connection to Building Piping

Gas-fired commercial cooking appliances installed on casters and appliances that are moved for cleaning and sanitation purposes shall be connected to the piping system with an appliance connector listed as complying with ANSI Z21.69/CSA 6.16. The commercial cooking appliance connector installation shall be configured in accordance with the manufacturer's installation instructions. Movement of appliances with casters shall be limited by a restraining device installed in accordance with the connector and appliance manufacturer's instructions. (IFC 606.4 2021)	The gas oven on casters in the kitchen is not limited by a restraining device.
--	--

3 Inspection and Maintenance

Opening protectives in fire-resistance-rated assemblies shall be inspected and maintained in accordance with NFPA 80. Opening protectives in smoke barriers shall be inspected and maintained in accordance with NFPA 80 and NFPA 105. Openings in smoke partitions shall be inspected and maintained in accordance with NFPA 105. Fire doors and smoke and draft control doors shall not be blocked, obstructed, or otherwise made inoperable. Fusible links shall be replaced promptly whenever fused or damaged. Opening protectives and smoke and draft control doors shall not be modified. (IFC 705.2 2021)	As per documentation provided the annual fire door inspection completed on 10/17/205 has multiple deficiencies that have not been corrected.
--	--

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Birchview Memory Care Community	Provider Number	2760
Address	925 DUNLOP AVE ,	Approval Status	Disapproved
City, State, Zip	Sedro-Woolley, WA	Facility Type	Residential Care

On 12/22/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

Next inspection scheduled on or after: 01/21/2026

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative


Signature


Abigail Camin, Maintenance Assistant
Print Name and Title

Deputy State Fire Marshal Brandon G. Brown
MP 235 SB Interstate 5
Bow WA 98232
(360) 791-7037


Signature

This document was prepared by Residential Care Services for the Locator website.