



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Warm Beach Health Care Center	Provider Number	000362
Address	20420 MARINE DR NW,	Approval Status	Approved
City, State, Zip	Stanwood, WA 98292	Facility Type	Residential Care

On 03/11/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

1 Admin Complaint

COMPLAINT # 169460

Here's a complaint of water outage

Please include the answers to the following questions in your report in FDM.

1. The cause of the fire?
2. If the sprinklers were activated?
3. If there was an evacuation / how many were evacuated?
4. If there were injuries / how many?
5. Did the fire department respond? Yes, No

Complaint ref # 169460

At 1100 on the 03/11/2025, DSFM Brown entered The Warm Beach Health Care Center located at 20420 Marine Dr, Stanwood, WA 98292 to investigate complaint ref# 169460.

On 03/02/2025 at 2100 the facility had a planned water outage until 0900 on 03/03/2025 for a sprinkler system repair for the independent living area which also interrupted the water supply to the assisted living. Facility was on fire watch for the entire outage period. Water was restored at 0200 on 03/03/2025. Sprinkler contractor was onsite 03/03/2025 to inspect the sprinkler system.

No injuries were report.

No violations observed.

Next inspection scheduled on or after:

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Signature

STEVE ANDERSON (DIRECTOR OF FACILITIES)
Print Name and Title

Deputy State Fire Marshal Brandon G. Brown
16778 146 ST SE
Monroe WA 98272
(360) 791-7037

Signature