



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Franke Tobey Jones Home Memory Care	Provider Number	
Address	5340 N BRISTOL ST ,	Approval Status	Approved
City, State, Zip	Tacoma, WA 98407	Facility Type	Residential Care

On 07/18/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

1 Admin Complaint

COMPLAINT # 137322

Here's a complaint of dry system down

Please include the answers to the following questions in your report in FDM.

1. The cause of the fire?
2. If the sprinklers were activated?
3. If there was an evacuation / how many were evacuated?
4. If there were injuries / how many?
5. Did the fire department respond? Yes, No

On July 18, 2024, an investigation for complaint ID # 137322, was performed at Franke Tobey Jones ALF. The complaint was in regards to a dry fire sprinkler system outage that occurred on July 5th, 2024 at about 2:00 a.m.

The facility's fire alarm alerted staff that the dry system's compressor had failed, which caused the system to fill with water. No residents were affected by the incident and no injuries were reported. Fire sprinkler contractors arrived later that morning (7/5) and had the system restored by 11:39 a.m.

No violations were detected with the facility response to the fire incident, and no IFC violations were observed.

Next inspection scheduled on or after:

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Vicki Weaver
Signature

Vicki Weaver - Building Services Coordinator
Print Name and Title

Deputy State Fire Marshal Lysandra Davis
2502 112 ST
Tacoma WA 984455104
(360) 890-1622

L Davis
Signature