



Washington State Patrol  
Fire Protection Bureau  
Phone: (360) 596-3900

**Business Name** Chehalis West Retirement Center Inc  
**Address** 478 NW QUINCY PL ,  
**City, State, Zip** Chehalis, WA

**Provider Number** 000783  
**Approval Status** Disapproved  
**Facility Type** Residential Care

On 06/24/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

**1 Inspection and Maintenance**

Opening protectives in fire-resistance-rated assemblies shall be inspected and maintained in accordance with NFPA 80. Opening protectives in smoke barriers shall be inspected and maintained in accordance with NFPA 80 and NFPA 105. Openings in smoke partitions shall be inspected and maintained in accordance with NFPA 105. Fire doors and smoke and draft control doors shall not be blocked, obstructed, or otherwise made inoperable. Fusible links shall be replaced promptly whenever fused or damaged. Opening protectives and smoke and draft control doors shall not be modified.

(IFC 705.2 2021)

The facility failed to provide an annual fire door inspection that included the inspection of fire door gaps

**2 Testing and Maintenance**

Sprinkler systems shall be tested and maintained in accordance with Section 901.

(IFC 903.5 2021)

**Next inspection scheduled on or after: 07/24/2025**

**Right of appeal.** Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.


Owner or Authorized Representative

Signature

C. Nika Storms executive director  
Print Name and Title

Deputy State Fire Marshal Nicholas Wolden  
1823 BAKER WAY  
Kelso WA 98626  
(360) 852-0966

Nicholas D. Wolden  
Signature

Initials of Authorized Facility Representative: 

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol  
Fire Protection Bureau  
Phone: (360) 596-3900

|                         |                                     |                        |                  |
|-------------------------|-------------------------------------|------------------------|------------------|
| <b>Business Name</b>    | Chehalis West Retirement Center Inc | <b>Provider Number</b> | 000783           |
| <b>Address</b>          | 478 NW QUINCY PL ,                  | <b>Approval Status</b> | Disapproved      |
| <b>City, State, Zip</b> | Chehalis, WA 98532                  | <b>Facility Type</b>   | Residential Care |

On 01/16/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

| Code Requirement | Statement of Violation |
|------------------|------------------------|
|------------------|------------------------|

### 1 Capacity Exceeding 1.5 Cubic Yards

Dumpsters and containers with an individual capacity of 1.5 cubic yards [40.5 cubic feet (1.15 m3)] or more shall not be stored in buildings or placed within 5 feet (1524 mm) of combustible walls, openings or combustible roof eave lines.

**Exceptions:**

1. Dumpsters or containers that are placed inside buildings in areas protected by an approved automatic sprinkler system installed throughout in accordance with Section 903.3.1.1, 903.3.1.2 or 903.3.1.3.
2. Storage in a structure shall not be prohibited where the structure is of Type I or IIA construction, located not less than 10 feet (3048 mm) from other buildings and used exclusively for dumpster or container storage.
3. Dumpsters or containers that are located adjacent to buildings where the exterior area is protected by an approved automatic sprinkler system.

(IFC 304.3.3 2021)

Dumpsters and containers with an individual capacity of 1.5 cubic yards [40.5 cubic feet (1.15 m3)] or more shall not be stored in buildings or placed within 5 feet (1524 mm) of combustible walls, openings or combustible roof eave lines.

### 2 Inspection and Maintenance

Opening protectives in fire-resistance-rated assemblies shall be inspected and maintained in accordance with NFPA 80.  
Opening protectives in smoke barriers shall be inspected and maintained in accordance with NFPA 80 and NFPA 105.  
Openings in smoke partitions shall be inspected and maintained in accordance with NFPA 105. Fire doors and smoke and draft control doors shall not be blocked, obstructed, or otherwise made inoperable. Fusible links shall be replaced promptly whenever fused or damaged. Opening protectives and smoke and draft control doors shall not be modified.

(IFC 705.2 2021)

The facility failed to provide an annual fire door inspection that included the inspection of fire door gaps

### 3 Testing and Maintenance

Sprinkler systems shall be tested and maintained in accordance with Section 901.

(IFC 903.5 2021)

Fire sprinkler trim ring adjar in room 5

Fire sprinkler system missing the partial trip test

This document was prepared by Residential Care Services for the locator website.





Washington State Patrol  
Fire Protection Bureau  
Phone: (360) 596-3900

|                         |                                     |                        |                  |
|-------------------------|-------------------------------------|------------------------|------------------|
| <b>Business Name</b>    | Chehalis West Retirement Center Inc | <b>Provider Number</b> | 000783           |
| <b>Address</b>          | 478 NW QUINCY PL ,                  | <b>Approval Status</b> | Disapproved      |
| <b>City, State, Zip</b> | Chehalis, WA 98532                  | <b>Facility Type</b>   | Residential Care |

On 01/16/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

**4 Commercial Cooking Systems**

904.13 Commercial cooking systems. The automatic fire-extinguishing system for commercial cooking systems shall be of a type recognized for protection of commercial cooking equipment and exhaust systems of the type and arrangement protected. Preengineered automatic dry- and wet-chemical extinguishing systems shall be tested in accordance with UL 300 and listed and labeled for the intended application. Other types of automatic fireextinguishing systems shall be listed and labeled for specific use as protection for commercial cooking operations. The system shall be installed in accordance with this code, NFPA 96, its listing and the manufacturer's installation instructions. Additional protection is not required for ductwork beyond 75 feet when hood suppression system complies with UL 300. Signage shall be provided on the exhaust hood or system cabinet, indicating the type and arrangement of cooking appliances protected by the automatic fire-extinguishing system. Signage shall indicate appliances from left to right, be durable, and the size, color, and lettering shall be approved. Automatic fireextinguishing systems of the following types shall be installed in accordance with the referenced standard indicated, as follows:

1. Carbon dioxide extinguishing systems, NFPA 12.
2. Automatic sprinkler systems, NFPA 13.
3. Automatic water mist systems, NFPA 750.
4. Foam-water sprinkler system or foam-water spray systems, NFPA 16.
5. Dry-chemical extinguishing systems, NFPA 17.
6. Wet-chemical extinguishing systems, NFPA 17A.

**EXCEPTIONS:**

1. Factory-built commercial cooking recirculating systems that are tested in accordance with UL 710B and listed, labeled and installed in accordance with Section 304.1 of the International Mechanical Code.
2. Protection of duct systems beyond 75 feet when the commercial kitchen exhaust hood is protected by a system listed in accordance with UL 300.

(IFC 904.13 2021 WAC 51-54A)

Signage shall be provided on the exhaust hood or system cabinet, indicating the type and arrangement of cooking appliances protected by the automatic fire-extinguishing system. Signage shall indicate appliances from left to right, be durable, and the size, color, and lettering shall be approved.

Instructions shall be provided to new employees on hiring and to all employees annually on the use of portable fire extinguishers and the manual actuation of the fire-extinguishing system. 14  
Records of compliance shall be maintained and shall be available to the authority having jurisdiction.

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol  
Fire Protection Bureau  
Phone: (360) 596-3900

|                         |                                     |                        |                  |
|-------------------------|-------------------------------------|------------------------|------------------|
| <b>Business Name</b>    | Chehalis West Retirement Center Inc | <b>Provider Number</b> | 000783           |
| <b>Address</b>          | 478 NW QUINCY PL ,                  | <b>Approval Status</b> | Disapproved      |
| <b>City, State, Zip</b> | Chehalis, WA 98532                  | <b>Facility Type</b>   | Residential Care |

On 01/16/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

**5 Portable Fire Extinguishers - General Requirements**

Portable fire extinguishers shall be selected, installed and maintained in accordance with this section and NFPA 10.

Exceptions:

1. The distance of travel to reach an extinguisher shall not apply. The travel distance to reach an extinguisher shall not apply to the spectator seating portions of Group A-5 occupancies.
2. Thirty-day inspections shall not be required and maintenance shall be allowed to be once every three years for dry-chemical or halogenated agent portable fire extinguishers that are supervised by a listed and approved electronic monitoring device, provided that all of the following conditions are met:
  - 2.1. Electronic monitoring shall confirm that extinguishers are properly positioned, properly charged and unobstructed.
  - 2.2. Loss of power or circuit continuity to the electronic monitoring device shall initiate a trouble signal.
  - 2.3. The extinguishers shall be installed inside of a building or cabinet in a noncorrosive environment.
  - 2.4. Electronic monitoring devices and supervisory circuits shall be tested every 3 years when extinguisher maintenance is performed.
  - 2.5. A written log of required hydrostatic test dates for extinguishers shall be maintained by the owner to verify that hydrostatic tests are conducted at the frequency required by NFPA 10.
3. In Group I-3, portable fire extinguishers shall be permitted to be located at staff locations.

(IFC 906.2 2021)

Fire extinguisher in laundry room found blocked by cart

This document was prepared by Residential Care Services for the Locator website.





Washington State Patrol  
Fire Protection Bureau  
Phone: (360) 596-3900

|                         |                                     |                        |                  |
|-------------------------|-------------------------------------|------------------------|------------------|
| <b>Business Name</b>    | Chehalis West Retirement Center Inc | <b>Provider Number</b> | 000783           |
| <b>Address</b>          | 478 NW QUINCY PL ,                  | <b>Approval Status</b> | Disapproved      |
| <b>City, State, Zip</b> | Chehalis, WA 98532                  | <b>Facility Type</b>   | Residential Care |

On 01/16/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

**6 Lock and Latches**

Locks and latches shall be permitted to prevent operation of doors where any of the following exists:

1. Places of detention or restraint.
2. In buildings in occupancy Group A having an occupant load of 300 or less, Groups B, F, M, and S, and in places of religious worship, the main door or doors are permitted to be equipped with key-operated locking devices from the egress side provided:
  - 2.1. The locking device is readily distinguishable as locked;
  - 2.2. A readily visible sign is posted on the egress side on or adjacent to the door stating: THIS DOOR TO REMAIN UNLOCKED WHEN BUILDING IS OCCUPIED. The sign shall be in letters 1 inch (25 mm) high on a contrasting background; and
  - 2.3. The use of the key-operated locking device is revocable by the building official for due cause.
3. Where egress doors are used in pairs, approved automatic flush bolts shall be permitted to be used, provided that the door leaf having the automatic flush bolts has no doorknob or surface-mounted hardware.
4. Doors from individual dwelling or sleeping units of Group R occupancies having an occupant load of 10 or less are permitted to be equipped with a night latch, dead bolt, or security chain, provided such devices are openable from the inside without the use of a key or a tool.
5. Fire doors after the minimum elevated temperature has disabled the unlatching mechanism in accordance with listed fire door test procedures.
6. Doors serving roofs not intended to be occupied shall be permitted to be locked preventing entry to the building from the roof.
7. Approved, listed locks without delayed egress shall be permitted in Group I-1 condition 2 assisted living facilities licensed under chapter 388-78A WAC and Group I-1 Condition 2 residential treatment facilities licensed under chapter 246-337 WAC by the state of Washington, provided that:
  - 7.1. The clinical needs of one or more patients require specialized security measures for their safety.
  - 7.2. The doors unlock upon actuation of the automatic sprinkler system or automatic fire detection system.

The facility failed to provided Instructions for exiting that is posted within six feet of the door in the memory care unit.

This document was prepared by Residential Care Services for the locator website.



Washington State Patrol  
Fire Protection Bureau  
Phone: (360) 596-3900

|                         |                                     |                        |                  |
|-------------------------|-------------------------------------|------------------------|------------------|
| <b>Business Name</b>    | Chehalis West Retirement Center Inc | <b>Provider Number</b> | 000783           |
| <b>Address</b>          | 478 NW QUINCY PL ,                  | <b>Approval Status</b> | Disapproved      |
| <b>City, State, Zip</b> | Chehalis, WA 98532                  | <b>Facility Type</b>   | Residential Care |

On 01/16/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

| Code Requirement                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                    | Statement of Violation |
|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------|
| 7.3. The doors unlock upon loss of electrical power controlling the lock or lock mechanism.<br>7.4. The lock shall be capable of being deactivated by a signal from a switch located in an approved location.<br>7.5. There is a system, such as a keypad and code, in place that allows visitors, staff persons and appropriate residents to exit. Instructions for exiting shall be posted within six feet of the door.<br>8. Other than egress courts, where occupants must egress from an exterior space through the building for means of egress, exit access doors shall be permitted to be equipped with an approved locking device where installed and operated in accordance with all of the following:<br>8.1. The occupant load of the occupied exterior area shall not exceed 300 as determined by IBC Section 1004.<br>8.2. The maximum occupant load shall be posted where required by Section 1004.9. Such sign shall be permanently affixed inside the building and shall be posted in a conspicuous space near all the exit access doorways.<br>8.3. A weatherproof telephone or two-way communication system installed in accordance with Sections 1009.8.1 and 1009.8.2 shall be located adjacent to not less than one required exit access door on the exterior side.<br>8.4. The egress door locking device is readily distinguishable as locked and shall be a key-operated locking device.<br>8.5. A clear window or glazed door opening, not less than 5 square feet (0.46 m2) sq. ft. in area, shall be provided at each exit access door to determine if there are occupants using the outdoor area.<br>8.6. A readily visible durable sign shall be posted on the interior side on or adjacent to each locked required exit access door serving the exterior area stating: THIS DOOR TO REMAIN UNLOCKED WHEN THE OUTDOOR AREA IS OCCUPIED. The letters on the sign shall be not less than 1 inch high on a contrasting background.<br>9. Locking devices are permitted on doors to balconies, decks, or other exterior spaces serving individual dwelling or sleeping units.<br>10. Locking devices are permitted on doors to balconies, |                        |

This document was prepared by Residential Care Services for the locator website.



Washington State Patrol  
Fire Protection Bureau  
Phone: (360) 596-3900

|                         |                                     |                        |                  |
|-------------------------|-------------------------------------|------------------------|------------------|
| <b>Business Name</b>    | Chehalis West Retirement Center Inc | <b>Provider Number</b> | 000783           |
| <b>Address</b>          | 478 NW QUINCY PL ,                  | <b>Approval Status</b> | Disapproved      |
| <b>City, State, Zip</b> | Chehalis, WA 98532                  | <b>Facility Type</b>   | Residential Care |

On 01/16/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

| Code Requirement                                                                                                                      | Statement of Violation |
|---------------------------------------------------------------------------------------------------------------------------------------|------------------------|
| decks, or other exterior spaces of 250 square feet or less, serving a private office space.oor.<br><br>(IFC 1010.2.4 2021 WAC 51-54A) |                        |

This document was prepared by Residential Care Services for the Locator website.





Washington State Patrol  
Fire Protection Bureau  
Phone: (360) 596-3900

|                         |                                     |                        |                  |
|-------------------------|-------------------------------------|------------------------|------------------|
| <b>Business Name</b>    | Chehalis West Retirement Center Inc | <b>Provider Number</b> | 000783           |
| <b>Address</b>          | 478 NW QUINCY PL ,                  | <b>Approval Status</b> | Disapproved      |
| <b>City, State, Zip</b> | Chehalis, WA 98532                  | <b>Facility Type</b>   | Residential Care |

On 01/16/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

**7 Alcohol-based hand rubs classified as Class I or II liquids.**

The use of wall-mounted dispensers containing alcohol-based hand rubs classified as Class I or II liquids shall be in accordance with all of the following:

1. The maximum capacity of each dispenser shall be 68 ounces (2 L).
2. The minimum separation between dispensers shall be 48 inches (1219 mm).
3. The dispensers shall not be installed above below or closer than 1 inch to a electrical receptacle, switch, appliance, device or other ignition source. The wall space between the dispenser and the floor or intervening counter top shall be free of electrical receptacles, switch's, appliances, devices or other ignition source. directly adjacent to, directly above or below an electrical receptacle, switch, appliance, device or other ignition source. The wall space between the dispenser and the floor shall remain clear and unobstructed.
4. Dispensers shall be mounted so that the bottom of the dispenser is a minimum of 42 inches (1067 mm) and a maximum of 48 inches (1219 mm) above the finished floor.
5. Dispensers shall not release their contents except when the dispenser is manually activated. Facilities shall be permitted to install and use automatically activated "touch free" alcohol-based hand-rub dispensing devices with the following requirements:
  - 5.1. The facility or persons responsible for the dispensers shall test the dispensers each time a new refill is installed in accordance with the manufacturers care and use instructions.
  - 5.2. Dispensers shall be designed and must operate in a manner that ensures accidental or malicious activations of the dispensing device are minimized. At a minimum, all devices subject to or used in accordance with this section shall have the following safety features:
    - 5.2.1. Any activations of the dispenser shall only occur when an object is placed within 4 inches (98 mm) of the

ABHR found dover electrical outlet

This document was prepared by Residential Care Services for the locator website.





Washington State Patrol  
Fire Protection Bureau  
Phone: (360) 596-3900

|                         |                                     |                        |                  |
|-------------------------|-------------------------------------|------------------------|------------------|
| <b>Business Name</b>    | Chehalis West Retirement Center Inc | <b>Provider Number</b> | 000783           |
| <b>Address</b>          | 478 NW QUINCY PL ,                  | <b>Approval Status</b> | Disapproved      |
| <b>City, State, Zip</b> | Chehalis, WA 98532                  | <b>Facility Type</b>   | Residential Care |

On 01/16/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

sensing device.

5.2.2. The dispenser shall not dispense more than the amount required for hand hygiene consistent with label instructions as regulated by the United States Food and Drug Administration (USFDA).

5.2.3. An object placed within the activation zone and left in place will cause only one activation.

6. Storage and use of alcohol-based hand rubs shall be in accordance with the applicable provisions of Sections 5704 and 5705.

7. Dispensers installed in occupancies with carpeted floors shall only be allowed in smoke compartments or fire areas equipped throughout with an approved automatic sprinkler system in accordance with Section 903.3.1.1 or 903.3.1.2.

(IFC 5705.5 2012)

Next inspection scheduled on or after: 02/15/2025

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

  
Signature

James Annett maintenance  
Print Name and Title

Deputy State Fire Marshal Nicholas Wolden  
1823 BAKER WAY  
Kelso WA 98626  
(360) 852-0966

  
Signature



Washington State Patrol  
Fire Protection Bureau  
Phone: (360) 596-3900

**Business Name**

478 NW QUINCY PL ,

**City, State, Zip**

Chehalis, WA 98532

**Provider Number** 000783

**Approval Status** Disapproved

**Facility Type** Residential Care

On 03/20/2025 the Office of the State Fire Marshal conducted a re-inspection at your facility. Listed below are violations that have not been corrected.

**Code Requirement**

**Statement of Violation**

**1 Inspection and Maintenance**

Opening protectives in fire-resistance-rated assemblies shall be inspected and maintained in accordance with NFPA 80. Opening protectives in smoke barriers shall be inspected and maintained in accordance with NFPA 80 and NFPA 105. Openings in smoke partitions shall be inspected and maintained in accordance with NFPA 105. Fire doors and smoke and draft control doors shall not be blocked, obstructed, or otherwise made inoperable. Fusible links shall be replaced promptly whenever fused or damaged. Opening protectives and smoke and draft control doors shall not be modified.

(IFC 705.2 2021)

The facility failed to provide an annual fire door inspection that included the inspection of fire door gaps

**2 Testing and Maintenance**

Sprinkler systems shall be tested and maintained in accordance with Section 901.

(IFC 903.5 2021)

Fire sprinkler system missing the partial trip test

This document was prepared by Residential Care Services for the Locator website.





Washington State Patrol  
Fire Protection Bureau  
Phone: (360) 596-3900

**Business Name**

478 NW QUINCY PL ,

**City, State, Zip**

Chehalis, WA 98532

**Provider Number** 000783

**Approval Status** Disapproved

**Facility Type** Residential Care

On 03/20/2025 the Office of the State Fire Marshal conducted a re-inspection at your facility. Listed below are violations that have not been corrected.

**Code Requirement**

**Statement of Violation**

**Next inspection scheduled on or after:** 04/19/2025

**Right of appeal.** Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

  
Signature

Deputy State Fire Marshal Nicholas Wolden  
1823 BAKER WAY  
Kelso WA 98626  
(360) 852-0966

  
Signature

This document was prepared by Residential Care Services for the Locator website.