



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Grandview Village Retirement Community	Provider Number	000977
Address	5800 64TH ST NE,	Approval Status	Approved
City, State, Zip	Marysville, WA	Facility Type	Residential Care

On 05/19/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

All violations noted during previous related inspection(s) have been corrected.

Owner or Owner's Representative

Signature

Jenn Young ED
Print Name and Title

Deputy State Fire Marshal Brandon G. Brown
MP 235 SB Interstate 5
Bow WA 98232
(360) 791-7037

Brandon Brown

Digitally signed by Brandon Brown
Date: 2026.05.19 15:18:24 -07'00'

Signature

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Grandview Village Retirement Community	Provider Number	000977
Address	5800 64TH ST NE,	Approval Status	Disapproved
City, State, Zip	Marysville, WA	Facility Type	Residential Care

On 05/14/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

1 Admin Complaint

COMPLAINT # 223970

Here's a complaint of Smoke Detector

Please include the answers to the following questions in your report in FDM.

1. The cause of the fire?
2. If the sprinklers were activated?
3. If there was an evacuation / how many were evacuated?
4. If there were injuries / how many?
5. Did the fire department respond? Yes, No

Complaint ref # 223970

At 1500 on 05/14/2026, DSFM Brown conducted complaint inspection for Grandview Village Retirement Community located at 5800 64th St NE, Marysville, WA 98270 to investigate complaint ref # 223970. I interviewed the Facility Executive Director.

On 05/02/2026, one smoke detector malfunctioned in the lobby/dining area. The alarm system vendor turned off the zone that was malfunctioning. The facility contacted the local fire department and started fire watch. I was contacted on 5/4/2026 and instructed the facility to contact DSHS. I authorized a modified fire watch, allowing the receptionist in the front entry to conduct the fire watch. Her desk can see the entire outage area. I also instructed them that they would need someone to conduct fire watch after her shift.

On 5/7/2026 the City of Marysville issued a letter to end the fire watch, despite the system not being corrected. When RCS conducted their investigation, she called me and informed me of the letter. I entered on 5/14/2026 and placed the facility back on fire watch.

Fire department did not respond.

No injuries were report.

2 Emergency Impairments

When unplanned impairments occur, appropriate emergency action shall be taken to minimize potential injury and damage. The impairment coordinator shall implement the steps outlined in Section 901.7.4

(IFC 901.7.5 2021)

The facility was not conducting fire watch inspection, when the lobby zone was not operational.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Grandview Village Retirement Community	Provider Number	000977
Address	5800 64TH ST NE,	Approval Status	Disapproved
City, State, Zip	Marysville, WA	Facility Type	Residential Care

On 05/14/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

Next inspection scheduled on or after: 06/13/2026

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Signature

Print Name and Title

Deputy State Fire Marshal Brandon G. Brown
MP 235 SB Interstate 5
Bow WA 98232
(360) 791-7037

Brandon Brown

Digitally signed by Brandon Brown
Date: 2026.05.18 07:18:34 -07'00'

Signature

Jenn Young ED

This document was prepared by Residential Care Services for the Locator website.