

Wisconsin Department of Health Services

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 0017768	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED R-C 05/01/2026
NAME OF PROVIDER OR SUPPLIER LEGACY OF DEFOREST (THE)		STREET ADDRESS, CITY, STATE, ZIP CODE 6639 PEDERSON CROSSING BLVD DE FOREST, WI 53532		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
{N 000}	Initial Comments On 04/29/2026, Surveyor conducted a standard licensing survey, verification visit and a complaint investigation at Legacy of DeForest, a CBRF located in DeForest, WI. As a result of the survey, 1 violation of Chapter DHS 83 was issued. Three violations from previous Statement of Deficiency (SOD) 2YBI14 were corrected. Under statutory provisions of Wis. Stat. Ch. 50, a \$200 revisit fee is being assessed. The complaint was unsubstantiated. Census: 17	{N 000}		
N 617	83.55(6)(b) Bath and toilet areas: water temperature The CBRF shall set the temperature of all water heaters connected to sinks, showers and tubs used by residents at a temperature of at least 140°F. The temperature of water at fixtures used by residents shall be automatically regulated by valves and may not exceed 115°F, except for CBRFs serving residents recovering from alcohol or drug dependency or clients of a government correctional agency. This Rule is not met as evidenced by: Based on observation and interview, the provider did not ensure that water temperature did not exceed 115 degrees Fahrenheit. There were 3 resident faucets that exceeded 115 degrees Fahrenheit.	N 617		

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Wisconsin Department of Health Services

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 0017768	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED R-C 05/01/2026
NAME OF PROVIDER OR SUPPLIER LEGACY OF DEFOREST (THE)		STREET ADDRESS, CITY, STATE, ZIP CODE 6639 PEDERSON CROSSING BLVD DE FOREST, WI 53532		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
N 617	Continued From page 1 Facility is able to serve up to 25 residents with diagnoses that include but not limited to: irreversible dementia/Alzheimer's, terminally ill, advanced age. Facility is a memory care unit that serves elderly residents that are more prone to injuries from hot water. Each resident has his/her own bathroom in his/her apartment. Findings include: On 04/29/2026 at 9:00 AM, Surveyor observed the physical environment. The water temperature in Resident 1's bathroom measured 121 degrees Fahrenheit. The water temperature in Resident 2's bathroom measured 121 degrees Fahrenheit. The water temperature in Resident 3's bathroom measured 123 degrees Fahrenheit. On 04/29/2026 at 10:30 AM, Surveyor interviewed Maintenance B and Director A. Maintenance B stated that there are several spots where water is heated and some areas of the building. Maintenance B acknowledged that water temperatures cannot exceed 115 degrees Fahrenheit. Maintenance B acknowledged that Resident 1, Resident 2 and Resident 3's faucet water temperature exceeded 115 degrees Fahrenheit. Director A stated that water temperatures will be monitored and adjusted accordingly.	N 617		