

Wisconsin Department of Health Services

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 0016465	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED C 07/25/2023
NAME OF PROVIDER OR SUPPLIER HAGGAI HOME		STREET ADDRESS, CITY, STATE, ZIP CODE 3136 W REICHERT PL MILWAUKEE, WI 53209		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
M 000	INITIAL COMMENTS On 07/25/2023, Surveyor conducted an abbreviated survey and 3 complaint investigations at Haggai Home. One deficiency was identified. Three complaints were unsubstantiated. Census: 3	M 000		
M 334	88.05(4)(b)1 FIRE SAFETY-SMOKE DETECTORS Every adult family home shall be equipped with one or more single station battery operated, electrically interconnected or radio signal emitting smoke detectors on each floor level. Required smoke detectors shall be located in each habitable room except the kitchen and bathroom and specifically in the following locations: at the head of each open stairway, at the door leading to every enclosed stairway, on the ceiling of the living room or family room, on the ceiling of each sleeping room and in the basement. This Rule is not met as evidenced by: Based on observation and interview, the provider did not ensure smoke detectors were maintained and working in 2 of 6 required locations. The head of the basement stairway and the living room did not contain working smoke detectors. Findings include: On 07/25/2023, at 12:55 PM, Surveyor toured the	M 334		

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Wisconsin Department of Health Services

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 0016465	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED C 07/25/2023
NAME OF PROVIDER OR SUPPLIER HAGGAI HOME			STREET ADDRESS, CITY, STATE, ZIP CODE 3136 W REICHERT PL MILWAUKEE, WI 53209		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
M 334	Continued From page 1 facility accompanied by Licensee A. Surveyor tested the smoke detector in the living room and at the head of the basement stairs and found they were not working. On 07/25/2023, at 12:55 PM, Surveyor interviewed Licensee A who confirmed the smoke detectors were not working. Licensee A stated, "they were all tested on July 7th and were working. I guess they must have died between then and now. I will replace the batteries as soon as possible."	M 334			