STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:	(X2) MULTIPLE CONSTRUCTION	(X3) DATE SURVEY COMPLETED
	0009180	A. BUILDING: _____ B. WING _____	R-C 07/17/2024

NAME OF PROVIDER OR SUPPLIER	STREET ADDRESS, CITY, STATE, ZIP CODE
PARADISE HOUSE	**3410 STRATFORD AVE RACINE, WI 53402**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
{M 000}	INITIAL COMMENTS On 07/17/2024, Surveyor conducted a verification visit and 2 complaint investigations. One deficiency was identified. One of 1 deficiency was a repeat violation (see SOD 5J0611 dated 07/29/2021). Two of 2 complaints were unsubstantiated. Under statutory provisions of Wis Stat. Ch. 50, a $200 revisit fee is being assessed. Census: 3	{M 000}		
{M 570}	88.10(3)(l) Safe Physical Environment Individuals, except for correctional residents, have basic rights which they do not lose when they enter an adult family home. A resident shall have a safe environment in which to live. The adult family home shall safeguard residents who cannot fully guard themselves from environmental hazards to which they are likely to be exposed, including conditions which would be hazardous to anyone and conditions which would be or are hazardous to a particular resident because of the resident's condition or disability. This Rule is not met as evidenced by: Based on observation and interview, the provider did not ensure a safe physical environment for 3 of 3 residents. The hot water was not kept at a safe temperature and measured 125° Fahrenheit (F) at 2 of 2 faucets tested. This is a repeat deficiency. See Statement of Deficiency (SOD) 5J0611, dated 07/29/2021.	{M 570}		

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE | TITLE | (X6) DATE

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:	(X2) MULTIPLE CONSTRUCTION	(X3) DATE SURVEY COMPLETED
	0009180	A. BUILDING: _____ B. WING _____	R-C 07/17/2024

NAME OF PROVIDER OR SUPPLIER	STREET ADDRESS, CITY, STATE, ZIP CODE
PARADISE HOUSE	**3410 STRATFORD AVE RACINE, WI 53402**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
{M 570}	Continued From page 1 Findings include: The provider is licensed as an ambulatory adult family home that may serve up to 4 residents within the client group of developmentally disabled. On 07/17/2024 at approximately 12:00 PM, Surveyor observed the hot water temperature from the bathroom and kitchen faucets was 125° F. Caregiver D confirmed the water temperature was 125° F. On 07/17/2024, at approximately 1:45 PM, Surveyor interviewed Administrator B about the hot water temperature. Administrator B expressed surprise it measured too high and stated they would turn the hot water temperature down. "Exposure to hot water is a potential environmental danger for residents. Elderly residents and residents with mental and physical disabilities may have neurological conditions that prevent instant recoil from hot water. Because these individuals do not instantly react to dangerous temperature levels, they are at particular risk for injury. Hot water can cause scalding, e.g., second and third degree burns in which the skin blisters and swells. In such instances, skin does not return to normal and forms scar tissue upon healing. These burns may lead to permanent disability." (DQA Publication-01942, Hot Water Temperatures in Adult Family Homes, August 2017.)	{M 570}		