

Wisconsin Department of Health Services

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 0012772	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 05/23/2025
NAME OF PROVIDER OR SUPPLIER SYCAMORE HOME		STREET ADDRESS, CITY, STATE, ZIP CODE 9211 66TH ST KENOSHA, WI 53142		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
N 000	Initial Comments On 05/23/2025, Surveyor conducted an abbreviated survey at Sycamore Home. One deficiency was identified. Census: 6	N 000		
N 617	83.55(6)(b) Bath and toilet areas: water temperature The CBRF shall set the temperature of all water heaters connected to sinks, showers and tubs used by residents at a temperature of at least 140°F. The temperature of water at fixtures used by residents shall be automatically regulated by valves and may not exceed 115°F, except for CBRFs serving residents recovering from alcohol or drug dependency or clients of a government correctional agency. This Rule is not met as evidenced by: Based on observation and interview, the provider did not ensure 4 of 4 bath and toilet areas had safe water temperatures. The water temperatures of 1 of 3 first floor bathroom sink faucets tested at 125° Fahrenheit (F). Two of 3 first floor bathroom sinks faucets, located in bedroom 3, tested at 122° F and 126° F. The second-floor bathroom sink faucet tested at 126° F. The temperature of water at fixtures used by residents shall be automatically regulated by valves and may not exceed 115°F. Findings include: On 08/01/2010, the provider was issued a regular license to care for 6 residents in the client group of developmentally disabled.	N 617		

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Wisconsin Department of Health Services

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 0012772	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 05/23/2025
NAME OF PROVIDER OR SUPPLIER SYCAMORE HOME		STREET ADDRESS, CITY, STATE, ZIP CODE 9211 66TH ST KENOSHA, WI 53142		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
N 617	Continued From page 1 On 05/23/2025, between 9:45 a.m. and 10:00 a.m., Surveyor tested the water temperature at 2 resident's bathroom faucets located in their bedrooms and 2 common bathroom faucets. The temperature readings were between 122°F and 126°F. The following was observed: -The 1st floor contained 3 bathrooms. Two of 3 first floor bathroom sinks faucets, located in bedroom 3, tested at 122° F and 126° F. The water temperatures of the first-floor common bathroom sink faucet tested at 125° F. -The 2nd floor contained 1 bathroom. The second-floor bathroom sink faucet tested at 126° F. On 05/23/2025, at 9:55 a.m., Surveyor and Program Director (PD) A tested water temperature in first floor bathroom sink faucet with facility thermometer. Surveyor and PD A observed facility thermometer time out at 119°-120° F. On 05/23/2025, at 9:55 a.m., Surveyor interviewed PD A regarding the hot water temperature. Surveyor asked PD A if s/he was aware of the code requirement. PD A reported s/he s/he was aware of the code. PD A reported staff was responsible to check water temperatures and report the temperatures back to him/her. PD A reported the temperatures had been running a little high. S/He did not realize that the thermometer was turning off at 119°-120° F. PD A stated s/he would order a new thermometer right away and s/he would have the water temperature decreased.	N 617		