

Wisconsin Department of Health Services

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 0012947	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED C 12/27/2023
NAME OF PROVIDER OR SUPPLIER WOODSTONE SENIOR LIVING CBRF		STREET ADDRESS, CITY, STATE, ZIP CODE 950 BEAR PAW AVE RICE LAKE, WI 54868		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
N 000	Initial Comments On 12/27/2023, Surveyor conducted 3 complaint investigations and a standard licensure survey at Woodstone Senior Living CBRF. Three of 3 complaints were unsubstantiated. One deficiency was identified. Census: 29	N 000		
N 488	83.44(1)(c) Clothes dryers enclosed and vented Clothes dryers. The CBRF shall enclose any clothes dryer having a rated capacity of more than 37,000 Btu/hour in a one-hour fire resistive rated enclosure. If the clothes dryer requires a vent, the CBRF shall use dryer vent tubing that is of rigid material with a fire rating that exceeds the temperature rating of the dryer. The dryer vent tubing shall be clean and maintained. This Rule is not met as evidenced by: Based on observation and interview, the provider did not ensure the clothes dryer vents were of rigid material. Findings include: The provider is licensed to care for up to 39 residents in the client groups of advanced aged and irreversible dementia/Alzheimer's disease. On 12/27/2023 at approximately 10:20 a.m., Surveyor observed the laundry room located in the care suites with Caregiver B. The dryer vent was a flexible tube and not rigid. At approximately 11:55 a.m., Surveyor observed the laundry room located in the memory care unit with Housekeeper C. The dryer vents were not rigid	N 488		

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Wisconsin Department of Health Services

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 0012947	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED C 12/27/2023
NAME OF PROVIDER OR SUPPLIER WOODSTONE SENIOR LIVING CBRF			STREET ADDRESS, CITY, STATE, ZIP CODE 950 BEAR PAW AVE RICE LAKE, WI 54868		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETE DATE
N 488	Continued From page 1 and were made of a flexible tubing. On 12/27/2023 at approximately 4:00 p.m., Surveyor interviewed Administrator A. Administrator A confirmed the dryer vents were not made of rigid material. S/he said s/he would have their maintenance person purchase and install rigid vent tubing.	N 488			