STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:	(X2) MULTIPLE CONSTRUCTION	(X3) DATE SURVEY COMPLETED
	0013142	A. BUILDING: _____ B. WING _____	04/08/2025

NAME OF PROVIDER OR SUPPLIER	STREET ADDRESS, CITY, STATE, ZIP CODE
T S RESIDENTIAL DEVELOPMENT HOME LLC	6440 N LANDERS ST MILWAUKEE, WI 53233

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
M 000	INITIAL COMMENTS On 04/08/2025, Surveyor conducted a standard survey at T S Residential Development Home LLC. One deficiency was identified. Census: 02	M 000		
M 332	88.05(4)(a) FIRE SAFETY-FIRE EXTINGUISHERS Fire extinguishers. Every adult family home shall be equipped with one or more fire extinguishers on each floor. Each required fire extinguisher shall have a minimum 2A, 10-B-C rating. All required fire extinguishers shall be mounted. A fire extinguisher is required at the head of each stairway and in or near the kitchen except that a single fire extinguisher located in close proximity to the kitchen and the head of a stairway may be used to meet the requirement for an extinguisher at each location. Each required fire extinguisher shall be maintained in readily usable condition and shall be inspected annually by the authorized dealer or the local fire department and have an attached tag showing the date of the last dealer or fire department inspection. This Rule is not met as evidenced by: Based on observation and interview, the provider did not ensure 2 of 2 fire extinguishers were checked annually by an authorized dealer or the local fire department. The fire extinguishers	M 332		

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE | TITLE | (X6) DATE

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:	(X2) MULTIPLE CONSTRUCTION	(X3) DATE SURVEY COMPLETED
	0013142	A. BUILDING: _____ B. WING _____	04/08/2025

NAME OF PROVIDER OR SUPPLIER	STREET ADDRESS, CITY, STATE, ZIP CODE
T S RESIDENTIAL DEVELOPMENT HOME LLC	6440 N LANDERS ST MILWAUKEE, WI 53233

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
M 332	Continued From page 1 located in the kitchen and the basement had annual inspection tags dated February 2024. Findings include: On 04/08/2025, at 1:30 PM, Surveyor observed a fire extinguishers mounted in the kitchen and the basement level. The annual inspection tags were dated February 2024. On 04/08/2024, at 1:35 PM, Surveyor interviewed Licensee A regarding fire extinguishers. Licensee A reported they knew of the requirement to get the fire extinguishers inspected and was surprised they were overdue. Licensee A stated, "We will have it done by end of day."	M 332		