

Wisconsin Department of Health Services

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 0008582	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED C 12/16/2024
NAME OF PROVIDER OR SUPPLIER PINE BROOK POINTE		STREET ADDRESS, CITY, STATE, ZIP CODE 1001 S PINE ST BURLINGTON, WI 53105		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
N 000	Initial Comments On 12/16/2024, Surveyor conducted a standard licensing survey and complaint investigation at Pine Brook Pointe, a CBRF located in Burlington, WI. As a result of the survey, 1 violation of Chapter DHS 83 was issued. The complaint was unsubstantiated. Census:	N 000		
N 488	83.44(1)(c) Clothes dryers enclosed and vented Clothes dryers. The CBRF shall enclose any clothes dryer having a rated capacity of more than 37,000 Btu/hour in a one-hour fire resistive rated enclosure. If the clothes dryer requires a vent, the CBRF shall use dryer vent tubing that is of rigid material with a fire rating that exceeds the temperature rating of the dryer. The dryer vent tubing shall be clean and maintained. This Rule is not met as evidenced by: Based on observation and interview, the provider did not ensure that 2 of 4 dryer vents were of rigid material. Two of 4 dryer vents were flex material. Findings include: On 12/16/2024, at approximately 11:45 AM, Surveyor toured the physical environment. The dryer on the second floor had a vent of flexible material. The dryer on the first floor had a vent of flexible material. On 12/16/2024 at 12:00 PM, Surveyor interviewed Administrator A. Administrator A acknowledged that dryer vents must be made of	N 488		

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Wisconsin Department of Health Services

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 0008582	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED C 12/16/2024
NAME OF PROVIDER OR SUPPLIER PINE BROOK POINTE			STREET ADDRESS, CITY, STATE, ZIP CODE 1001 S PINE ST BURLINGTON, WI 53105		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
N 488	Continued From page 1 rigid material. Administrator A acknowledged that 2 of 4 dryers had vents that were made of flexible material.	N 488			