

Wisconsin Department of Health Services

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 0017908	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 09/19/2025
NAME OF PROVIDER OR SUPPLIER AARNA FAMILY CARE LLC		STREET ADDRESS, CITY, STATE, ZIP CODE 3823 MEACHEM ROAD MOUNT PLEASANT, WI 53403		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
M 000	INITIAL COMMENTS On 09/19/2025, Surveyor conducted an abbreviated survey at Aarna Family Care. As a result, 2 deficiencies were identified. Census: 0	M 000		
M 332	88.05(4)(a) FIRE SAFETY-FIRE EXTINGUISHERS Fire extinguishers. Every adult family home shall be equipped with one or more fire extinguishers on each floor. Each required fire extinguisher shall have a minimum 2A, 10-B-C rating. All required fire extinguishers shall be mounted. A fire extinguisher is required at the head of each stairway and in or near the kitchen except that a single fire extinguisher located in close proximity to the kitchen and the head of a stairway may be used to meet the requirement for an extinguisher at each location. Each required fire extinguisher shall be maintained in readily usable condition and shall be inspected annually by the authorized dealer or the local fire department and have an attached tag showing the date of the last dealer or fire department inspection. This Rule is not met as evidenced by: Based on observation and interview the provider did not ensure 2 of 2 fire extinguishers were inspected annually. The fire extinguisher in the kitchen and the fire extinguisher in the basement was last inspected January 2020.	M 332		

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Wisconsin Department of Health Services

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 0017908	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 09/19/2025
NAME OF PROVIDER OR SUPPLIER AARNA FAMILY CARE LLC		STREET ADDRESS, CITY, STATE, ZIP CODE 3823 MEACHEM ROAD MOUNT PLEASANT, WI 53403		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
M 332	Continued From page 1 Findings include: On 09/19/2025, at 11:20 AM, Surveyor toured the facility. The fire extinguisher had an inspection tag which indicated it was last serviced January 2020. The fire extinguisher in the basement had an inspection tag which indicated it was last serviced January 2020. On 09/19/2025, at 11:35 AM, Surveyor interviewed Licensee A. Licensee A confirmed the code requirement. Licensee A reported there were no residents in the home since it was licensed, and s/he would ensure the fire extinguishers were serviced right away.	M 332		
M 570	88.10(3)(l) Safe Physical Environment Individuals, except for correctional residents, have basic rights which they do not lose when they enter an adult family home. A resident shall have a safe environment in which to live. The adult family home shall safeguard residents who cannot fully guard themselves from environmental hazards to which they are likely to be exposed, including conditions which would be hazardous to anyone and conditions which would be or are hazardous to a particular resident because of the resident's condition or disability. This Rule is not met as evidenced by: Based on observation and interview, the provider did not ensure a safe physical environment by ensuring water temperatures were kept at a safe temperature for 1 of 1 bathroom. The hot water	M 570		

Wisconsin Department of Health Services

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 0017908	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 09/19/2025
NAME OF PROVIDER OR SUPPLIER AARNA FAMILY CARE LLC		STREET ADDRESS, CITY, STATE, ZIP CODE 3823 MEACHEM ROAD MOUNT PLEASANT, WI 53403		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
M 570	Continued From page 2 temperature in the resident bathroom was 129.7 ° Fahrenheit (F). Findings include: The facility was licensed as a non-ambulatory adult family home (AFH), to serve residents in client groups traumatic brain injury, emotionally disturbed/mental illness, physically disabled, irreversible dementia/Alzheimer's, advanced age and developmentally disabled. On 09/16/2025, at 11:25 AM, Surveyor tested the water temperature in the bathroom sink faucet. The water temperature was 129.7 °F. "Exposure to hot water is a potential environmental danger for residents. Elderly residents and residents with mental and physical disabilities may have neurological conditions that prevent instant recoil from hot water. Because these individuals do not instantly react to dangerous temperature levels, they are at particular risk for injury. Hot water can cause scalding; e.g. second and third degree burns in which the skin blisters and swells. In such instances, skin does not return to normal and forms scar tissue upon healing. These burns may lead to permanent disability." (DQA Publication-01942, Hot Water Temperatures in Adult Family Homes, August 2017) On 09/19/2025, at 11:35 AM, Surveyor interviewed Licensee A. Licensee A reported s/he would turn the water heater down.	M 570		