STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:	(X2) MULTIPLE CONSTRUCTION	(X3) DATE SURVEY COMPLETED
	0014238	A. BUILDING: _____ B. WING _____	09/04/2025

NAME OF PROVIDER OR SUPPLIER	STREET ADDRESS, CITY, STATE, ZIP CODE
ELK CREEK	13032 ELK CREEK VIOLA, WI 54664

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
M 000	INITIAL COMMENTS On 09/04/2025, Surveyor conducted a standard licensing survey at Elk Creek, an AFH in Viola, WI. One deficiency of Chapter DHS 88 was identified. Census: 3	M 000		
M 334	88.05(4)(b)1 FIRE SAFETY-SMOKE DETECTORS Every adult family home shall be equipped with one or more single station battery operated, electrically interconnected or radio signal emitting smoke detectors on each floor level. Required smoke detectors shall be located in each habitable room except the kitchen and bathroom and specifically in the following locations: at the head of each open stairway, at the door leading to every enclosed stairway, on the ceiling of the living room or family room, on the ceiling of each sleeping room and in the basement. This Rule is not met as evidenced by: Based on observation and interview, the provider did not ensure there was a smoke detector in all required locations. There was no smoke detector in the home's basement or living room. Findings include: On 09/04/2025 at approximately 8:45 AM, Surveyor conducted a tour of the home with	M 334		

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE | TITLE | (X6) DATE

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:	(X2) MULTIPLE CONSTRUCTION	(X3) DATE SURVEY COMPLETED
	0014238	A. BUILDING: _____ B. WING _____	09/04/2025

NAME OF PROVIDER OR SUPPLIER	STREET ADDRESS, CITY, STATE, ZIP CODE
ELK CREEK	13032 ELK CREEK VIOLA, WI 54664

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
M 334	Continued From page 1 House Manager A. There was no smoke detector in the living room. There was no smoke detector in the basement, though there was a mount where one had previously been installed. House Manager A found a smoke detector in a cupboard upstairs and installed it in the basement while Surveyor was on site. On 09/04/2025 at approximately 9:35 AM, Surveyor interviewed House Manager A. House Manager A stated the living room was remodeled over the end of the 2023 year and early into 2024 and believed there was a smoke detector in the living room prior to that. S/he did not have an explanation for why one had not been reinstalled. House Manager A stated the smoke detector in the basement was probably removed in the past to change batteries, and thought staff got busy and forgot to reinstall it.	M 334		