

06/08/2012 09:08 FAX 9073581881

RECEIVED
WY Dept of Health
AUG 15 2012

DOUGLAS CARE CENTER

RECEIVED Healthcare Licensing
WY Dept of Health
AUG 08 2012

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

004/082

PRINTED: 07/25/2012
FORM APPROVED
OMB NO. 0938-0301

STATEMENT OF DEFICIENCIES PLAN OF CORRECTION		(K1) PROVIDER/PLAN/PERSONAL IDENTIFICATION NUMBER: 698040		MULTIPLE CONSTRUCTION A LONG TERM CARE LICENSING BUILDING 01 and Surveys		(K2) DATE SURVEY COMPLETED 07/12/2012	
NAME OF PROVIDER OR SUPPLIER DOUGLAS CARE CENTER LLC				STREET ADDRESS, CITY, STATE, ZIP CODE 1108 NUNCH STREET DOUGLAS, WY 82033			
(K4) IS PREP TAB	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREP TAB	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		
K000	INITIAL COMMENTS Requirements for the Long Term Care Facilities Section 42 CFR 483.70 (a) except as otherwise provided in the section, the facility must meet the applicable provisions of the 2000 edition of the Life Safety Code, existing Health Care, of the National Fire Protection Association. The facility was a fully sprinklered single story building of Type V (111) construction built in 1987, and remodeled in 2010. The building was equipped with a supervised automatic wet sprinkler system with a combination zoned and addressable fire alarm system. The facility had a capacity of 60 certified Medicare and Medicaid beds. K018 88=D NFPA 101 LIFE SAFETY CODE STANDARD Doors protecting corridor openings in other than required enclosures of vertical openings, exits, or hazardous areas are substantial doors, such as those constructed of 1 1/2 inch solid-banded core wood, or capable of resisting fire for at least 20 minutes. Doors in sprinklered buildings are only required to resist the passage of smoke. There is no impediment to the closing of the doors. Doors are provided with a means suitable for keeping the door closed. Dutch doors meeting 19.3.6.3.6 are permitted. 19.3.6.3 Roller latches are prohibited by CMS regulations in all health care facilities.			K000	K018 Resident rooms #111 and 206 have been adjusted to ensure that the device used shall be capable of keeping the door fully closed if a force of 5LBF is applied at the latch edge of the door. Dec maintenance will monitor resident room doors quarterly to ensure no more than 5lb force is required to close. Results to be reported to QA quarterly.		

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE SIGNATURE

[Signature]

TITLE

NHA

DATE

8/2/12

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that
the deficiency provides sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 60 days
following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14
days following the date these documents are made available to the facility. If a deficiency is cited, an approved plan of correction is required to continued
program participation.

FORM CMS-2567 (02-99) Previous Versions Obsolete

Event ID: 2567021

Facility ID: WY0010

If continuation sheet Page 1 of 4

Approved & changes to TC to ADM on 8/15/12 @ 2:48 PM
PS 1, 3, 4

[Signature]

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICESPRINTED: 07/26/2012
FORM APPROVED
OMB NO. 0938-0381

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(C1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 835040		(C2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____		(C3) DATE SURVEY COMPLETED 07/12/2012	
NAME OF PROVIDER OR SUPPLIER DOUGLAS CARE CENTER LLC				STREET ADDRESS, CITY, STATE, ZIP CODE 1106 BIRCH STREET DOUGLAS, WY 82633			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	DATE COMPLETION DATE			
K 016	Continued From page 1	K 016					
	This STANDARD is not met as evidenced by: Based on observation and staff interview, the facility failed to ensure 2 corridor doors were resistant to the passage of smoke in 2 of 6 smoke compartments. The findings were: Observation on 7/11/12 between 11 AM and 3:30 PM revealed the corridor doors to resident rooms #111 and #206 did not close completely in their frames unless force in excess of 5 foot pounds of pressure was applied. The facility administrator verified these findings at the time of the observation. Reference: NFPA 101, Life Safety Code, 2000 edition, Section 19.3.6.3.2. (existing) 19.3.6.3.2 Doors shall be provided with a means suitable for keeping the door closed that is acceptable to the authority having jurisdiction. The device used shall be capable of keeping the door fully closed if a force of 15lb is applied at the latch edge of the door. NFPA 101 LIFE SAFETY CODE STANDARD						
K 029 SS=D	One hour fire rated construction (with ¾ hour fire-rated doors) or an approved automatic fire extinguishing system in accordance with 8.4.1 and/or 19.3.8.4 protects hazardous areas. When the approved automatic fire extinguishing system option is used, the areas are separated from other spaces by smoke resisting partitions and doors. Doors are self-closing and non-rated or field-applied protective plates that do not exceed 48 inches from the bottom of the door are permitted. 19.3.2.1	K 029					

FORM CMS-2567(02-99) Previous Versions Obsolete

Event ID: ERN021

Facility ID: WY0018

If continuation sheet Page 2 of 4

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 07/25/2012
FORM APPROVED
CMS NO. 0828-0391

STATEMENT OF DEFICIENCIES PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 833640	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING of B. WING		(X3) DATE SURVEY COMPLETED 07/12/2012
NAME OF PROVIDER OR SUPPLIER DOUGLAS CARE CENTER LLO			STREET ADDRESS, CITY, STATE, ZIP CODE 1105 BIRCH STREET DOUGLAS, WY 82833		
(X4) IC NURSE TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	IC3 COMPLETION DATE	
K 029	Continued From page 2 This STANDARD is not met as evidenced by: Based on observation and staff interview, the facility failed to ensure 1 door with a self closure device was operating properly in 1 of 5 smoke compartments. The findings were: Observation on 7/11/12 at 10:48 AM revealed the door to the soiled linen room across from resident room #101 had a self closure device (SCD) attached. However, the door did not latch into its frame with three separate attempts. Interview with the facility administrator at the time of the observation confirmed the findings. Ref. 2000 NFPA 101 Section 18.3.2.1, 8.4.1.2, 8.2.4.3.5 18.3.2.1 Hazardous Areas. Any hazardous area shall be protected in accordance with Section 8.4.1.2 in new construction, where protection is provided with automatic extinguishing systems without fire-resistive separation, the space protected shall be enclosed with smoke partitions in accordance with 8.2.4. 8.2.4.3.5 Doors shall be self-closing or automatic-closing in accordance with 7.2.1.6. 7.2.1.6 Self Closing Devices. A door normally required to be kept closed shall not be secured in the open position at any time and shall be self-closing or automatic closing in accordance with 7.2.1.6.2.	K 029	The door going in to the soiled linen room across from resident room #101 that has a self closure device attached that did not latch into its frame has now been adjusted and will close into its frame. 9/1/12 DCC Maintenance on 8/24/12 DCC will monitor all doors & SCD on a quarterly basis and brought to QA on a quarterly basis.		
K 147 83=0	NFPA 101 LIFE SAFETY CODE STANDARD Electrical wiring and equipment is in accordance with NFPA 70, National Electrical Code. 9.1.2	K 147			

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 07/25/2012
FORM APPROVED
OMB NO. 0938-0397

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(01) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 536040	(02) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____		(03) DATE SURVEY COMPLETED 07/12/2012
NAME OF PROVIDER OR SUPPLIER DOUGLAS CARE CENTER LLC			STREET ADDRESS, CITY, STATE, ZIP CODE 1109 BIRCH STREET DOUGLAS, WY 82633		
(04) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(05) COMPLETION DATE	
K 147	Continued From page 2 This STANDARD is not met as evidenced by: Based on observation and staff interview, the facility failed to provide electrical wiring in accordance with NFPA 70, National Electric Code, in 1 of 5 smoke compartments. The findings were: Observation on 7/11/12 at 11:48 AM revealed an electrical wall outlet was missing its face plate cover in the clean linen room in the special care unit. The facility administrator acknowledged the finding at the time of the observation. Reference: 2000 NFPA 101 Section 18.5.1 (existing), section 9.1.2; Reference: NFPA 70, National Electrical Code, 1999 Edition.	K 147	K147 The face plate that was missing at the electrical wall outlet in the clean linen room in the special care unit has been replaced and now has a electrical face plate. <i>See maintenance on 8/20/12 designer will monitor all electrical wall outlets on a quarterly basis and report to QA quarterly</i>	9/1/12	