

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 08/10/2012
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 53A049	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____	(X3) DATE SURVEY COMPLETED 07/24/2012
NAME OF PROVIDER OR SUPPLIER GOSHEN CARE CENTER			STREET ADDRESS, CITY, STATE, ZIP CODE 2009 LARAMIE STREET TORRINGTON, WY 82240	
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 000	INITIAL COMMENTS Requirements for Long Term Care Facilities Section 42 CFR 483.70 (a) except as otherwise provided in the section, the facility must meet the applicable provisions of the 2000 edition of the Life Safety Code, Existing Health Care, of the National Fire Protection Association. The facility was a fully sprinkled single story building of Type V (111) construction built in 1998. The building was equipped with a supervised automatic wet sprinkler system with a dry branch and an addressable fire alarm system that communicates with the Alzheimer's building. The facility had a capacity of 75 certified Medicaid beds with a census of 71.	K 000		
K 064 SS=D	NFPA 101 LIFE SAFETY CODE STANDARD Portable fire extinguishers are provided in all health care occupancies in accordance with 9.7.4.1. 19.3.5.6, NFPA 10 This STANDARD is not met as evidenced by: Based on observation and staff interview, the facility failed to ensure portable fire extinguishers was maintained in 1 of 6 smoke compartments. The findings were: Observation of the kitchen on 7/24/12 at 1:54 PM showed the "K" type fire extinguisher had a 5-year hydrostatic test performed in 2006. Further observation showed a 5-year hydrostatic test was not performed during the November 2011 annual service. At the time of the observation the facility	K 064	"K" type fire extinguisher in the kitchen has been replaced with a "K" type loaner by contract vender. 7/31/12 "K" type fire extinguisher for the kitchen has been taken to be hydro tested. Completion date: by 8/31/12 "K" type fire extinguishers are checked annually by Nebraska Fire & Safety. This will be reported annually to Safety.	7/31/12 8/31/12

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE *Natalie Korrell, Administrator* TITLE _____ (X8) DATE 8/17/12

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

AUG 20 2012 *RECEIVED W/ Mary Hove, DON, on 9/5/12*
FORM CMS-2567(02-99) Previous Versions Obsolete Event ID: OSWO21 Facility ID: WY0010 If continuation sheet Page 1 of 3

Healthcare Licensing
and Surveys

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 08/10/2012
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 53A049	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 07/24/2012
NAME OF PROVIDER OR SUPPLIER GOSHEN CARE CENTER			STREET ADDRESS, CITY, STATE, ZIP CODE 2009 LARAMIE STREET TORRINGTON, WY 82240 9/5/12		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
K 064	Continued From page 1 operation senior manager could not explain why the contractor had not performed the required service. Reference NFPA 101, 2000 Edition, 19.3.5.6, 9.7.4.1, NFPA 10, 1998 Edition; Table 5-2 Hydrostatic Test Intervals for Extinguishers Wet Agent-----5 years	K 064			
K 070 SS=D	NFPA 101 LIFE SAFETY CODE STANDARD Portable space heating devices are prohibited in all health care occupancies, except in non-sleeping staff and employee areas where the heating elements of such devices do not exceed 212 degrees F. (100 degrees C) 19.7.8 This STANDARD is not met as evidenced by: Based on observation and staff interview, the facility failed to ensure space heaters in non-sleeping staff areas were maintained in 1 of 6 smoke compartments. The findings were: Observation of the infection control office on 7/24/12 at 9:49 AM showed a space heater was in use. Further observation showed the heater had not been tested to ensure the maximum temperature did not exceed 212 degrees. At the time of the observation the facility operation senior manager could not explain why the heater had not been noticed and tested or removed during the quarterly inspections.	K 070	The space heater has been removed. Completed 7/27/12 This will be monitored by EVS Staff will report quarterly to safety committee.		7/27/12
K 147 SS=D	NFPA 101 LIFE SAFETY CODE STANDARD Electrical wiring and equipment is in accordance	K 147	Tag K147 to begin on the next page		

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 08/10/2012
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 53A049	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 07/24/2012
NAME OF PROVIDER OR SUPPLIER GOSHEN CARE CENTER			STREET ADDRESS, CITY, STATE, ZIP CODE 2009 LARAMIE STREET TORRINGTON, WY 82240		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 147	Continued From page 2 with NFPA 70, National Electrical Code. 9.1.2 This STANDARD is not met as evidenced by: Based on observation and staff interview, the facility failed to ensure damaged electrical appliances were replaced in 1 of 6 smoke compartments. The findings were: Observation of resident room #201 on 7/24/12 at 10:17 AM showed the power cord to the bed was damaged at the plug. The interior wires were exposed where the outer sheath had been damaged. At the time of the observation the facility operation senior manager could not explain why the housekeeping staff had not noticed and replace the cord during the daily rounds. Reference NFPA 101, 2000 Edition, 19.5.1, 9.1.2, NFPA 70, 1999 Edition; 90-7 Examination of Equipment for Safety. ...It is the intent of this Code that factory-installed internal wiring or the construction of equipment need not be inspected at the time of installation of the equipment, except to detect alterations of damage ...	K 147	The three prong plug has been replaced on the bed in room 201. Completion date: 7/27/12 Electrical cords will be monitored by EVS Staff weekly. EVS Supervisor will be report quarterly to Safety Committee.	7/27/12	

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 08/10/2012
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 53A049	(X2) MULTIPLE CONSTRUCTION A. BUILDING 02 - ALZHEIMERS BUILDING B. WING _____		(X3) DATE SURVEY COMPLETED 07/24/2012
NAME OF PROVIDER OR SUPPLIER GOSHEN CARE CENTER			STREET ADDRESS, CITY, STATE, ZIP CODE 2009 LARAMIE STREET TORRINGTON, WY 82240		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 000	INITIAL COMMENTS Requirements for Long Term Care Facilities Section 42 CFR 483.70 (a) except as otherwise provided in the section, the facility must meet the applicable provisions of the 2000 edition of the Life Safety Code, New Health Care, of the National Fire Protection Association. The facility was a fully sprinkled single story building of Type V (111) construction built in 2007. The building was equipped with a supervised automatic wet sprinkler system with a dry branch and an addressable fire alarm system that communicates with the main building. The facility had a capacity of 28 certified Medicaid beds with a census of 27.	K 000			
K 147 SS=D	NFPA 101 LIFE SAFETY CODE STANDARD Electrical wiring and equipment is in accordance with NFPA 70, National Electrical Code. 9.1.2 This STANDARD is not met as evidenced by: Based on observation and staff interview, the facility failed to ensure damaged electrical appliances were replaced in 1 of 3 smoke compartments. The findings were: Observation of resident room #519 on 7/24/12 at 10:50 AM showed the power cord to the oxygen concentrator was damaged at the plug. The interior wires were exposed where the outer sheath had been damaged. At the time of the observation the facility operation senior manager could not explain why the housekeeping staff had not noticed and replace the cord during the daily rounds.	K 147	This concentrator with frayed cord will be reported and picked up by contract vendor. The concentrator has been removed and replaced with inspected concentrator from vendor. Completion date: 7/27/12 Electrical cord on concentrators will be checked on weekly EVS walk through. EVS Supervisor will report to Safety Committee quarterly.	7/27/12	

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

Natalie Korrell

TITLE

Admini Strator

(X6) DATE

8/17/12

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

for ACCEPTED w/ Mary Howe, DON, ON 9/5/12.

[Signature]

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 08/10/2012
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 53A049	(X2) MULTIPLE CONSTRUCTION A. BUILDING 02 - ALZHEIMERS BUILDING B. WING _____		(X3) DATE SURVEY COMPLETED 07/24/2012
NAME OF PROVIDER OR SUPPLIER GOSHEN CARE CENTER			STREET ADDRESS, CITY, STATE, ZIP CODE 2009 LARAMIE STREET TORRINGTON, WY 82240		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
K 147	Continued From page 1 Reference NFPA 101, 2000 Edition, 18.5.1.1, 9.1.2, NFPA 70, 1999 Edition; 90-7 Examination of Equipment for Safety. ...It is the intent of this Code that factory-installed internal wiring or the construction of equipment need not be inspected at the time of installation of the equipment, except to detect alterations of damage ...	K 147	This page left blank intentionally		