

WDH - Office of Healthcare Licensing and Surveys

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: WY0032	(X2) MULTIPLE CONSTRUCTION A. BUILDING _____ B. WING _____	(X3) DATE SURVEY COMPLETED 09/02/2010
NAME OF PROVIDER OR SUPPLIER SUBLETTE CENTER		STREET ADDRESS, CITY, STATE, ZIP CODE 333 N BRIDGER AVE PINEDALE, WY 82841		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X6) COMPLETE DATE
SNH	LIC REQS FOR NURSING HOMES This State Rules and Regulations is not met as evidenced by: Section 6. Physical Environment (a) The building(s) of the Nursing Care Facility shall be constructed, arranged and maintained to ensure the health and welfare of all residents. (iv) Shower/bath and resident lavatories shall be set to provide water of a temperature not to exceed 110 degrees Fahrenheit. This requirement was not met as evidenced by: Based on staff interview and observation in 3 of 3 resident rooms the hot water temperatures exceeded the required maximum temperatures on all three wings. Findings were: Observation on 9/1/10 at 1:45 PM with the maintenance director and utilizing the digital thermometer used by maintenance staff to monitor water temperatures revealed the following temperatures in the noted resident rooms were greater than 110 degrees Fahrenheit (F): a. Resident room #108 - 116 degrees F. b. Resident room #206 - 112 degrees F. c. Resident room #3 - 116 degrees F. Interview with the maintenance director at the time of the observation verified the water heaters were set at 120 degrees F., which was as low as they could be set.	SNH	The facility will ensure shower/bath and resident lavatories shall be set to provide water of a temperature not to exceed 110 degrees Fahrenheit as evidenced by: 1. The Maintenance Director (MD) will reduce the temperature setting on the water heating boiler feeding the East and West wings to 110 degrees fahrenheit thereby reducing the water temperature in resident rooms #108 and #206, and all rooms on these wings to the State maximum standard temperature of 110 degrees fahrenheit. 2. The MD will install a water tempering valve on the discharge of the electric water heaters feeding the North wing thereby reducing the water temperature in room #3, and all rooms on this wing to the State maximum standard temperature of 110 degrees fahrenheit. 3. The MD will monitor water temperature 5 times a week by reading an in-line thermometer that will be installed on the outgoing water lines. The MD will also monitor water temperature on a weekly basis using a hand held infrared thermometer. Thermometer readings will be charted and a record kept on file in the Maintenance Department. The MD will report at the quarterly QAA meeting with appropriate follow up	10/17/2010

Wyoming Dept of Health, Office of Healthcare Licensing and Surveys

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

ADMINISTRATOR

(X6) DATE

9/24/10

STATE FORM

0900

09MV11

RECEIVED

Wyoming Dept of Health

SEP 28 2010

NOV 17 2010

Office of Healthcare
Licensing and Surveys

Office of Healthcare
Licensing and Surveys