

PRINTED: 12/17/2014
FORM APPROVED

Healthcare Licensing and Surveys

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: WY0032	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 12/04/2014
NAME OF PROVIDER OR SUPPLIER SUBLETTE CENTER		STREET ADDRESS, CITY, STATE, ZIP CODE 333 N BRIDGER AVE PINEDALE, WY 82841		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
S2924	Ch 11 Sec 6 (a)(iv) Physical Environment (a) The building(s) of the Nursing Care Facility shall be constructed, arranged and maintained to ensure the health and welfare of all residents. (iv) Shower/bath and resident lavatories shall be set to provide water of a temperature not to exceed 110 degrees Fahrenheit. This State Rule and Regulation is not met as evidenced by: Based on observation and staff interview, the facility failed to ensure water temperatures were 110 degrees Fahrenheit (F) or less in 2 of 3 resident areas (north hallway, east hallway). The findings were: Observation on 12/4/14 from 8:06 AM through 8:16 AM showed the following sink water temperatures were above 110 degrees F: room #4 = 118 degrees F, room #7 = 114 degrees F, room #8 = 116 degrees F, room #9 = 114 degrees F, room #6 = 116 degrees F, main dining room sink (used by residents) = 112 degrees F, and room #205 = 112 degrees F. Interview with the maintenance director on 12/4/14 at 9 AM showed he did not check water temperatures in individual rooms. Instead, he observed the thermometer in the water system just outside of the hot water heater. Observation at that time showed the hot water heater thermometer registered 110 degrees F. However, the maintenance director used an independent thermometer and checked water temperatures in resident rooms and confirmed the water temperatures taken by the surveyors were correct.	S2924:	Ch 11 Sec 6 (a)(iv) Physical Environment The facility will ensure that (a) the buildings of the Nursing Care Facility shall be constructed, arranged and maintained to ensure the health and welfare of all residents and (iv) shower/bath and resident lavatories shall be set to provide water of a temperature not to exceed 110 degrees Fahrenheit by: A) For North hallway and East hallway, rooms #4, #7, #6, #9, #205: Tempering valve was adjusted on 12/03/2014 by maintenance team, who also established a routine method for monitoring water temperatures on 12/04/2014, which now include individual rooms. Maintenance team will monitor water temperatures weekly and report any findings as a function of quarterly QA.	12/4/14 1/15/15 jc

Wyoming Dept of Health, Aging Division, Healthcare Licensing and Surveys
LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

STATE FORM

PEXR11

Continuation sheet 1 of 1

Don M Walker
changed note per phae call with Wendy Fied, Don
on 1/15/15 @ 10:49am.
Janelle Galt, ONIC