

Healthcare Licensing and Surveys

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: WY0022	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 01/20/2015
NAME OF PROVIDER OR SUPPLIER PLATTE COUNTY MEMORIAL NURSING HOME		STREET ADDRESS, CITY, STATE, ZIP CODE 204 15TH STREET WHEATLAND, WY 82201		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
S 000	General Comments A Life Safety Code survey was conducted at your facility on January 20, 2015 by the office of Healthcare Licensing and Surveys. (HLS) The facility was a fully sprinklered, single story building of Type V (111) construction built in 1965 and the east wing was a single story building of Type II (111) construction with a basement, built in 1978. The building was equipped with a supervised, automatic wet sprinkler system with an anti-freeze loop and an addressable fire alarm system. The facility had a capacity of 43 certified Medicare and Medicaid beds with a census of 39. Wyoming Department of Health, Rules and Regulations for Licensure of Nursing Care Facilities Chapter 19, Section 8 Life Safety and Electrical Safety. The requirements in the Department of Health Chapter III, Construction Rules for Health Facilities apply.	S 000	This plan of correction is submitted as required under State and Federal law. This plan does not constitute admission of liability on the part of the facility and such liability is hereby specifically denied. The submission of this plan does not constitute agreement by the facility that the surveyors' findings or conclusions are accurate, that the findings constitute a deficiency or that the scope or severity regarding the deficiencies cited are correctly applied.	
S7026	NFPA Life Safety - Nfpa Electric NFPA 101 Electric This State Rule and Regulation is not met as evidenced by: Based on observation and staff interview, the facility failed to ensure that the electrical wiring and equipment was in accordance with NFPA 70. The findings were: Observation of the crawl space under the east wing on 01/20/15 at 12:26 PM revealed two extension cords that were plugged in to the exhaust fans that provide fresh air to the space. The Facility Maintenance Manager at the time of the observation acknowledge the use of the	S7026	S7026 - The extension cords that were plugged into the exhaust fans have been removed and both exhaust fans were hard wired into the electrical system on 1/28/15. An audit will be conducted of the facility to ensure that no extension cords are permanently in use. Maintenance will conduct monthly rounds for three months and then quarterly thereafter to ensure that no extension cords are being used incorrectly in the facility. Results will be taken to QA&A for further review and analysis.	3/6/15

Wyoming Dept of Health, Aging Division, Healthcare Licensing and Surveys
LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

STATE FORM

6099

8CKE11

If continuation sheet 1 of 2

POC Accepted via Phone Call with Administrator
Shane Filipi on 2-19-15 at 3:09 pm
JMK 34354

Healthcare Licensing and Surveys

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: WY0022	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 01/20/2015
NAME OF PROVIDER OR SUPPLIER PLATTE COUNTY MEMORIAL NURSING HOME			STREET ADDRESS, CITY, STATE, ZIP CODE 204 15TH STREET WHEATLAND, WY 82201		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
S7026	Continued From page 1 extension cords. Ref: 2000 NFPA 101, Sections 19.5.1 and 9.1.2 Ref: 1999 NFPA 70, Article 305	S7026			