

Apr. 20. 2015 1:14AM

No. 3433 P. 38

PRINTED: 04/08/2016
FORM APPROVED

Healthcare Licensing and Surveys

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: WY0003	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 03/26/2015
NAME OF PROVIDER OR SUPPLIER THERMOPOLIS REHABILITATION AND CARE C			STREET ADDRESS, CITY, STATE, ZIP CODE PO BOX 1325 THERMOPOLIS, WY 82449		
(X4) ID PREFIX TAG 82924	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG 82924	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
	Ch 11 Sec 6 (a)(iv) Physical Environment (a) The building(s) of the Nursing Care Facility shall be constructed, arranged and maintained to ensure the health and welfare of all residents. (iv) Shower/bath and resident lavatories shall be set to provide water of a temperature not to exceed 110 degrees Fahrenheit. This State Rule and Regulation is not met as evidenced by: Based on observation and staff interview, the facility failed to ensure water temperatures were 110 degrees Fahrenheit (F) or less in 8 random observations of resident areas. The findings were: 1. Observation on 3/26/15 from 8:30 AM to 8:47 AM showed the following sink water temperatures were above 110 degrees F: room #4 114 degrees F, room #5 113.7 degrees F, B Hall shower room 115.5 degrees F, room #8 114.8 degrees F, room #9 115.3 degrees F, Therapy room 112 degrees F, room #22 112.6 degrees F, and room #24 113.2 degrees F. 2. Interview with the maintenance director on 3/26/15 at 8:30 AM revealed he did not check temperatures in individual rooms and confirmed the temperatures obtained by the surveyor at that time.		The facility will ensure that Shower/bath and resident lavatories shall be set to provide water of a temperature not to exceed 110 degrees Fahrenheit. 2. All residents are affected. 3. On 3/26/15 Maintenance manager adjusted hot water thermostat to 108 degrees Fahrenheit. Maintenance staff will be in-serviced on Ch 11 Sec 6 (a) (iv) Physical Environment that the facility will ensure that Shower/bath and resident lavatories shall be set to provide water of a temperature not to exceed 110 degrees Fahrenheit. 4. Director of Maintenance/designee will monitor per the facility PM guide monthly. Findings to QA monthly. 5. Completed by 5/25/15.		

Wyoming Dept of Health, Aging Division, Healthcare Licensing and Surveys
LABORATORY DIRECTOR OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

STATE FORM

TITLE

(X6) DATE

NHA
Administrator
4/16/15
POC accepted. Case to Brenda Fisher, doc on 5/11/15 @ 1:50pm.
Janelle Corbin, DPK

If continuation sheet 1 of 1