

Healthcare Licensing and Surveys

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: WY0010	(X2) MULTIPLE CONSTRUCTION A. BUILDING: <u>Healthcare Licensing and Surveys</u> B. WING: <u>and Surveys</u>	(X3) DATE SURVEY COMPLETED 12/15/2015
---	---	---	---

NAME OF PROVIDER OR SUPPLIER

STREET ADDRESS, CITY, STATE, ZIP CODE

GOSHEN HEALTHCARE COMMUNITY

2009 LARAMIE STREET
TORRINGTON, WY 82240

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
S 000	General Comments A Life Safety Code survey was conducted at your facility on December 16, 2015 by the office of Healthcare Licensing and Surveys. (HLS) The facility was a fully sprinklered, single story building of Type V (111) construction built in 1998 and 2007. The building was equipped with a supervised, automatic wet sprinkler system with a dry branch and an addressable fire alarm system. The facility had a capacity of 103 certified Medicaid beds with a census of 83.	S 000		
S7036	IPC Life Safety - Int'l Plumbing Code This State Rule and Regulation is not met as evidenced by: Based on observation and staff interview, the facility failed to maintain the existing plumbing systems in a manner that is in accordance with the WDH Chapter 3 Construction Rules and Regulations for Healthcare Facilities, in accordance with the original design, and in a safe and sanitary condition. The findings were: Observation of the emergency eyewash stations located throughout the Care Center and Special Care Unit on 12/15/15 from 11:25 AM to 2:30 PM revealed that tepid water was not provided to the eyewash via an ASSE 1071 - Performance Requirements for Temperature Actuated Mixing Valves for Plumbed Emergency Equipment - mixing valve in compliance with ANSI Z358.1 - Standard for Emergency Eye Wash and Shower Equipment. An interview with the Facility Maintenance Manager at the time of the observations confirmed that the eyewash was not provided with a tempering valve in compliance with the requirements of ANSI Z358.1.	S7036	S7036 IPC Life Safety - Int'l Plumbing Code Corrective Actions: All Emergency eyewash stations that did not possess the temperature actuated mixing valves were uninstalled or converted to be compliant with ANSI Z358.1. Systemic Changes: All residents have the potential to be affected by this practice. A visual audit of all eyewash stations will be conducted by the Maintenance Director or designee to determine compliance to ANSI Z358.1. All found not compliant will be uninstalled or converted. Systemic Changes: The Maintenance Department will be educated on the requirements for Temperature Actuated Mixing Valves for Plumbed Emergency Equipment.	2/1/2016

Wyoming Dept of Health, Aging Division, Healthcare Licensing and Surveys
LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

STATE FORM

EDIM1

If continuation sheet 1 of 2

POC Accepted via Phone Call w/ M Administrator
Michael Sperdel on 1/19/16 @ 12:54pm
34384

Healthcare Licensing and Surveys

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: WY0010	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 12/15/2015
NAME OF PROVIDER OR SUPPLIER GOSHEN HEALTHCARE COMMUNITY		STREET ADDRESS, CITY, STATE, ZIP CODE 2009 LARAMIE STREET TORRINGTON, WY 82240			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
S7036	Continued From page 1 Ref: 2006 IPC, Sections 411	S7036	Monitoring: A weekly audit on compliance and functioning of all eyewash stations will be conducted by the Maintenance Director or designee x 30 days, then monthly x 90 days, until compliance has been determined to have been met by the QAPI Committee.		