

Healthcare Licensing and Surveys

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: ALF024	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 05/10/2016
NAME OF PROVIDER OR SUPPLIER BEEHIVE HOME OF BUFFALO		STREET ADDRESS, CITY, STATE, ZIP CODE 1 NORTH KLONDIKE BUFFALO, WY 82834		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
S 000	General Comments A Life Safety Code survey was conducted at your facility on May 10, 2016 by Health Care Licensing and Surveys (HLS). The survey revealed the building meets the Life Safety Code standards based on compliance with all provisions. The facility was a single story fully sprinklered building of Type V (000) construction built in 1998. The building was equipped with a supervised automatic wet 13R sprinkler system with an addressable fire alarm system. The facility had a capacity of 15 licensed beds with a census of 5 residents. Wyoming Department of Health Rules and Regulations for Licensure of Assisted Living Facilities Chapter 4, Section 10 Life Safety and Electrical Safety. The requirements in the Department of Health Chapter III, Construction Rules for Health Facilities apply. (ii) Assisted Living Facilities operation prior to the effective date of these rules shall meet the Life Safety Code of the National Fire Protection Association that was in effect at the time the facility was licensed as an Assisted Living Facility. All references are based on the requirements of NFPA 101 Life Safety Code, New Board and Care, 1994 Edition unless otherwise noted.	S 000		

Wyoming Dept of Health, Aging Division, Healthcare Licensing and Surveys
LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE