

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICESPRINTED: 11/18/2016
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 636050	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 11/01/2016
NAME OF PROVIDER OR SUPPLIER MORNING STAR CARE CENTER			STREET ADDRESS, CITY, STATE, ZIP CODE 4 NORTH FORK ROAD FORT WASHAKIE, WY 82514		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 000	INITIAL COMMENTS Requirements for Long Term Nursing Homes Section 42 CFR 483.70 (a) except as otherwise provided in the section, the facility must meet the applicable provisions of the 2012 Edition of the Life Safety Code, Existing Health Care of the National Fire Protection Association. The facility was a fully sprinklered, one-story building of Type V (III) construction built in 1983. The building was equipped with a supervised automatic dry sprinkler with dry pendent heads and an addressable zoned fire alarm system. The facility had a capacity of 45 certified Medicare and Medicaid beds with a census of 36.	K 000			
K 321 SS=D	NFPA 101 Hazardous Areas - Enclosure Hazardous Areas - Enclosure 2012 EXISTING Hazardous areas are protected by a fire barrier having 1-hour fire resistance rating (with 3/4-hour fire rated doors) or an automatic fire extinguishing system in accordance with 8.7.1. When the approved automatic fire extinguishing system option is used, the areas shall be separated from other spaces by smoke resisting partitions and doors in accordance with 8.4. Doors shall be self-closing or automatic-closing and permitted to have nonrated or field-applied protective plates that do not exceed 48 inches from the bottom of the door. Describe the floor and zone locations of hazardous areas that are deficient in REMARKS. 19.3.2.1 Area Automatic Sprinkler Seperation N/A a. Boiler and Fuel-Fired Heater Rooms	K 321	A) The west soiled utility room door will be adjusted and or sanded down so as the door may close with the use of a self-closing device. B) All residents and staff could be affected if a fire was to break out in the room and the door wasn't closed smoke would then fill that smoke compartment. Maintenance will observe and audit all doors with a self-closing device monthly. C) Environmental Services Manager will in-service Maintenance staff on 2012 NFPA 101 19.3.2.1.	11/7/16 Ad	

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Tamara A. Reed

Interim Administrator

11/28/16

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the Institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

SPOKE WITH TAMARA REED ON 12-9-16
VIA PHONE CALL TO ACCEPT THIS POL.

12-9-16

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 11/18/2016
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 535050	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 11/01/2016
NAME OF PROVIDER OR SUPPLIER MORNING STAR CARE CENTER			STREET ADDRESS, CITY, STATE, ZIP CODE 4 NORTH FORK ROAD FORT WASHAKIE, WY 82514		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 321	Continued From page 1 b. Laundries (larger than 100 square feet) c. Repair, Maintenance, and Paint Shops d. Soiled Linen Rooms (exceeding 64 gallons) e. Trash Collection Rooms (exceeding 64 gallons) f. Combustible Storage Rooms/Spaces (over 50 square feet) g. Laboratories (if classified as Severe Hazard - see K3220) This STANDARD is not met as evidenced by: Based on observation and staff interview, the facility failed to protect Hazardous areas in accordance with NFPA 101 in 1 of 5 smoke compartments. Observation on 11/01/2016 at 1:55 PM located in the 100 corridor and known to the facility as the west soiled utility revealed that door would not close with with the self closing device. Further observation revealed that the door was dragging on the finished floor and needed assistance for the door to close. Interview with the Facility Maintenance Manager at the time of observation indicated that there could be some settlement issues and that they were unaware of the door not closing properly.	K 321	D) Environmental Services Manager will report observations and audits to the Quality Assurance Committee at the QAPI meetings.	12/18/16 Ad	
K 511 SS=D	Ref: 2012 NFPA 101, Sections 19.3.2.1.3 NFPA 101 Utilities - Gas and Electric Utilities - Gas and Electric Equipment using gas or related gas piping complies with NFPA 54, National Fuel Gas Code, electrical wiring and equipment complies with NFPA 70, National Electric Code. Existing installations can continue in service provided no hazard to life.	K 511	A1) Maintenance will replace the breaker filler plate in Panel F1. A2) The receptacle will be replaced with a ground fault circuit interrupter receptacle.	11/8/16 11/8/16 Ad	

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 11/18/2016
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 535050	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 11/01/2016
NAME OF PROVIDER OR SUPPLIER MORNING STAR CARE CENTER			STREET ADDRESS, CITY, STATE, ZIP CODE 4 NORTH FORK ROAD FORT WASHAKIE, WY 82514		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 511	Continued From page 2 18.5.1.1, 19.5.1.1, 9.1.1, 9.1.2 This STANDARD is not met as evidenced by: Based on observation and staff interview, the facility failed to provide electrical panels in accordance with NFPA 70. 1. Observation on 11/01/2016 at 1:11 PM located at the break room/electrical room revealed that Panel F1 was missing a circuit breaker. Further observation revealed that there was no cover or device to prevent a persons hand from coming in contact with the circuit. Interview with the Facility Maintenance Manager at the time of the observation said that they did not notice the missing circuit breaker. Ref: 2012 NFPA 101, Sections 19.5.1.1 and 9.1.2 2011 NFPA 70, Section 408.7 2. Observation on 11/01/2016 at 2:10 PM located in the Medicine Storage room revealed a receptacle that was not of the ground-fault circuit-interrupter type within 6 feet of a sink. Interview with the Facility Maintenance Manager at the time of observation indicated that they overlooked the missing ground-fault circuit-interrupter. Ref: 2012 NFPA 101, Sections 19.5.1.1 and 9.1.2 2011 NFPA 70, Section 210.8(B)(5)	K 511	B1) All residents and staff could be affected if they were to open up an electrical panel and their finger went into the opening of breaker hole. Maintenance will observe and audit all electrical panels to ensure the safety of all residents and staff. B2) All residents and staff could be affected if the electrical product got water in it and short circuited. Maintenance will observe and audit all receptacles within 6 feet of sinks that they are a ground fault circuit interrupter receptacle. C) Environmental Services Manager will in-service Maintenance staff on 2012 NFPA 10119.5.1.1. and 9.1.2, 2011 NFPA 70 section 408.7. D) Environmental Service Manager will report observations and audits to the Quality Assurance Committee at the QAPI meetings.	12/8/16 AS	
K 918 SS-D	NFPA 101 Electrical Systems - Essential Electric System	K 918	A) A remote stop button for generator will be installed on the outside of generator room		

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 11/18/2016
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 535050	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 11/01/2016
NAME OF PROVIDER OR SUPPLIER MORNING STAR CARE CENTER			STREET ADDRESS, CITY, STATE, ZIP CODE 4 NORTH FORK ROAD FORT WASHAKIE, WY 82514		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 918	Continued From page 3 Electrical Systems - Essential Electric System Maintenance and Testing The generator or other alternate power source and associated equipment is capable of supplying service within 10 seconds. If the 10-second criterion is not met during the monthly test, a process shall be provided to annually confirm this capability for the life safety and critical branches. Maintenance and testing of the generator and transfer switches are performed in accordance with NFPA 110. Generator sets are inspected weekly, exercised under load 30 minutes 12 times a year in 20-40 day intervals, and exercised once every 36 months for 4 continuous hours. Scheduled test under load conditions include a complete simulated cold start and automatic or manual transfer of all EES loads, and are conducted by competent personnel. Maintenance and testing of stored energy power sources (Type 3 EES) are in accordance with NFPA 111. Main and feeder circuit breakers are inspected annually, and a program for periodically exercising the components is established according to manufacturer requirements. Written records of maintenance and testing are maintained and readily available. EES electrical panels and circuits are marked and readily identifiable. Minimizing the possibility of damage of the emergency power source is a design consideration for new installations. 6.4.4, 6.5.4, 6.6.4 (NFPA 99), NFPA 110, NFPA 111, 700.10 (NFPA 70) This STANDARD is not met as evidenced by: Based on observation and staff interview, the facility failed to provide an essential electric system in accordance with NFPA 110.	K 918	B) All residents and staff could be affected if the generator was running, the generator room was locked and the generator needed to be shut down. Once remote stop button is installed it will be tested to ensure that the generator will stop. C) Environmental Services Manager will in-service Maintenance staff on 2012 NFPA 101 sections 19.5.1.1 and 9.1.3 also 2010 NFPA section 5.6.5.6. D) Environmental service Manager will report observations and audits to the Quality Assurance Committee at the QAPI meetings.	12/18/16 	

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 11/18/2016
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 536060	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 11/01/2016
NAME OF PROVIDER OR SUPPLIER MORNING STAR CARE CENTER			STREET ADDRESS, CITY, STATE, ZIP CODE 4 NORTH FORK ROAD FORT WASHAKIE, WY 82514		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 918	Continued From page 3 Electrical Systems - Essential Electric System Maintenance and Testing The generator or other alternate power source and associated equipment is capable of supplying service within 10 seconds. If the 10-second criterion is not met during the monthly test, a process shall be provided to annually confirm this capability for the life safety and critical branches. Maintenance and testing of the generator and transfer switches are performed in accordance with NFPA 110. Generator sets are inspected weekly, exercised under load 30 minutes 12 times a year in 20-40 day intervals, and exercised once every 36 months for 4 continuous hours. Scheduled test under load conditions include a complete simulated cold start and automatic or manual transfer of all EES loads, and are conducted by competent personnel. Maintenance and testing of stored energy power sources (Type 3 EES) are in accordance with NFPA 111. Main and feeder circuit breakers are inspected annually, and a program for periodically exercising the components is established according to manufacturer requirements. Written records of maintenance and testing are maintained and readily available. EES electrical panels and circuits are marked and readily identifiable. Minimizing the possibility of damage of the emergency power source is a design consideration for new installations. 6.4.4, 6.5.4, 6.6.4 (NFPA 99), NFPA 110, NFPA 111, 700.10 (NFPA 70) This STANDARD is not met as evidenced by: Based on observation and staff interview, the facility failed to provide an essential electric system in accordance with NFPA 110.	K 918	B) All residents and staff could be affected if the generator was running, the generator room was locked and the generator needed to be shut down. Once remote stop button is installed it will be tested to ensure that the generator will stop. C) Environmental Services Manager will in-service Maintenance staff on 2012 NFPA 101 sections 19.5.1.1 and 9.1.3 also 2010 NFPA section 5.6.5.6. D) Environmental service Manager will report observations and audits to the Quality Assurance Committee at the QAPI meetings.	12/18/16 AS	

FORM CMS-2567 (02-99) Previous Versions Obsolete

Event ID: 68RH21

Facility ID: WY0017

If continuation sheet Page 4 of 5

