

PRINTED: 03/07/2017
FORM APPROVED

Healthcare Licensing and Surveys

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: WY0009	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 02/24/2017
NAME OF PROVIDER OR SUPPLIER CROOK COUNTY MEDICAL SERVICES DISTRI		STREET ADDRESS, CITY, STATE, ZIP CODE 713 OAK STREET SUNDANCE, WY 82729		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
S 000	OPENING COMMENTS Rules and Regulations utilized for this survey are: Rules and Regulations for Program Administration of Nursing Care Facilities, Chapter 11, effective 06/26/2000 Rules and Regulations for Licensure of Nursing Care Facilities, Chapter 19, effective 06/26/2000 A licensure survey was conducted by Healthcare Licensing and Surveys on 2/21/17 through 2/24/17.	S 000		
S2924	Ch 11 Sec 6 (a)(iv) Physical Environment (a) The building(s) of the Nursing Care Facility shall be constructed, arranged and maintained to ensure the health and welfare of all residents. (iv) Shower/bath and resident lavatories shall be set to provide water of a temperature not to exceed 110 degrees Fahrenheit. This State Rule and Regulation is not met as evidenced by: Based on observation and staff interview the facility failed to ensure hot water temperatures in resident bathrooms and showers did not exceed 110 degrees Fahrenheit (F) in 3 of 3 resident areas (short hall, long hall, and the shower room) The findings were: 1. Observation of the short hall rooms on 2/23/17 showed the following: a. At 2:06 PM the temperature of the bathroom sink hot water in room 201 measured 111.6 degrees F. b. At 2:10 PM the temperature of the bathroom sink hot water in room 202 measured 112.7 degrees F.	S2924	S2924 The Hot water mixing valve was reset to ensure water does not exceed 110 degrees F. Water temperatures will be checked monthly and logged on the Maintenance log. Corrections will be made to the temperature at the time of the check if necessary. The maintenance logs will be reviewed by the QAPI committee monthly with further actions to be decided after 3 months.	03/13/2017

Wyoming Dept of Health, Aging Division, Healthcare Licensing and Surveys
LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

STATE FORM

5599

EWFH11

If continuation sheet 1 of 2

RECEIVED

MAR 13 2017

Healthcare Licensing and Surveys

State Accepted
Cathy Spaulding
3.14.17

PRINTED: 03/07/2017
FORM APPROVED

Healthcare Licensing and Surveys

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: WY0009	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 02/24/2017
NAME OF PROVIDER OR SUPPLIER CROOK COUNTY MEDICAL SERVICES DISTRICT		STREET ADDRESS, CITY, STATE, ZIP CODE 713 OAK STREET SUNDANCE, WY 82729		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
S2924	Continued From page 1 c. At 2:12 PM the temperature of the bathroom sink hot water in room 204 measured 113.9 degrees F. 2. Observation of the long hall rooms on 2/23/17 showed the following: a. At 2:18 PM the temperature of the bathroom sink hot water in room 205 measured 113.1 degrees F. b. At 2:21 PM the temperature of the bathroom sink hot water in room 214 measured 111.5 degrees F. c. At 2:24 PM the temperature of the bathroom sink hot water in room 215 measured 112.7 degrees F. 3. Observation of the shower room on 2/22/17 at 2:28PM showed the temperature of the bathroom sink hot water measured 113.5 degrees F. 4. Interview with the maintenance director on 2/24/17 at 8:28 AM confirmed the hot water temperatures were above the limit of 110 degrees F. He further stated the temperatures were checked on a quarterly basis.	S2924		

Cathy [Signature]
3/14/17