

Healthcare Licensing and Surveys

RECEIVED

PRINTED: 05/04/2017
FORM APPROVED

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: WY0013	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 04/20/2017
--	--	--	--

NAME OF PROVIDER OR SUPPLIER
LIFE CARE CENTER OF CASPER

STREET ADDRESS, CITY, STATE, ZIP CODE
**4041 SOUTH POPLAR STREET
CASPER, WY 82601**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
S 000	OPENING COMMENTS Rules and Regulations utilized for this survey are: Rules and Regulations for Program Administration of Nursing Care Facilities, Chapter 11, effective 08/26/2000 Rules and Regulations for Licensure of Nursing Care Facilities, Chapter 18, effective 08/26/2000 A licensure survey was conducted by Healthcare Licensing and Surveys on 4/17/17 through 4/20/17.	S 000	Life Safety POC (Fed and State) Preparation and execution of this response and plan of correction does not constitute an admission or agreement by the provider of the truth of the facts alleged or conclusions set forth in the statement of deficiencies. The plan of correction is prepared and/or solely because it is required by the provisions of the state and federal law. For the purposes of any allegation that the facility is not in substantial compliance with the federal requirements of participation, this response and plan of correction constitutes the facility's allegation of compliance in accordance with the state operations manual.	
S2924	Ch 11 Sec 8 (a)(iv) Physical Environment (a) The building(s) of the Nursing Care Facility shall be constructed, arranged and maintained to ensure the health and welfare of all residents. (iv) Shower/bath and resident lavatories shall be set to provide water of a temperature not to exceed 110 degrees Fahrenheit. This State Rule and Regulation is not met as evidenced by: Based on observation and staff interview the facility failed to ensure water temperatures did not exceed 110 degrees Fahrenheit (F) in a variety of rooms on 2 of 3 units (unit 1 and unit 2). The findings were: 1. Observation with the maintenance director on 4/16/17 beginning at 5:05 PM revealed the following concerns regarding water temperatures in resident areas: a. The bathroom sink in room #105 had a hot water temperature of 113 degrees F. b. The bathroom sink in room #119 had a hot water temperature of 114.2 degrees F. c. The bathroom sink in room #112 had a hot	S2924	5/14/2017 - Completion Date S2924 1. The main water line mixing valve supplying water to this area of the building was adjusted down (cooler) on 05/10/17. All temps taken since the adjustment have been under 110 degrees. 2. This is the only mixing valve supplying this area of the building.	5/14/17

Wyoming Dept of Health, Aging Division, Healthcare Licensing and Surveys
LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

STATE FORM

SWSY11

If continuation sheet 1 of 2

Healthcare Licensing and Surveys

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: WY0013	(X2) MULTIPLE CONSTRUCTION A. BUILDING: B. WING: je	(X3) DATE SURVEY COMPLETED 04/20/2017
---	---	--	---

NAME OF PROVIDER OR SUPPLIER LIFE CARE CENTER OF CASPER	STREET ADDRESS, CITY, STATE, ZIP CODE 4041 SOUTH POPLAR STREET CASPER, WY 82601
--	---

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
S2024	Continued From page 1 water temperature of 112.7 degrees F. d. The sink in the resident shower room on Unit 1 had a hot water temperature of 114 degrees F. e. The bathroom sink in room #248 had a hot water temperature of 111.6 degrees F. f. The sink in the resident shower room on Unit 2 had a hot water temperature of 111 degrees F. g. The bathroom sink in room #207 had a hot water temperature of 111.7 degrees F. 2. Interview with the maintenance director on 4/20/17 at 9:06 AM verified he monitored water temperatures and the temperatures had not been a problem. However, he confirmed the temperature of the hot water during the observation exceeded 110 degrees F.	S2024	3. The Director on Maintenance will continue his daily water temp log to ensure the water temps remain under 110 degrees. 4. The results of his daily logs will be reviewed each month at PI.	