

Healthcare Licensing and Surveys

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: WY0024	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 06/22/2017
--	--	--	--

NAME OF PROVIDER OR SUPPLIER
POWELL VALLEY CARE CENTER

STREET ADDRESS, CITY, STATE, ZIP CODE
**777 AVENUE H
POWELL, WY 82435**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
S 000	OPENING COMMENTS Rules and Regulations utilized for this survey are: Rules and Regulations for Program Administration of Nursing Care Facilities, Chapter 11, effective 06/26/2000 Rules and Regulations for Licensure of Nursing Care Facilities, Chapter 19, effective 06/26/2000 A licensure survey was conducted by Healthcare Licensing and Surveys from 6/19/17 to 6/22/17.	S 000		
S2924	Ch 11 Sec 6 (a)(iv) Physical Environment (a) The building(s) of the Nursing Care Facility shall be constructed, arranged and maintained to ensure the health and welfare of all residents. (iv) Shower/bath and resident lavatories shall be set to provide water of a temperature not to exceed 110 degrees Fahrenheit. This State Rule and Regulation is not met as evidenced by: Based on observation, staff interview, and review of facility logs, the facility failed to ensure hot water temperatures in resident bathrooms did not exceed 110 degrees Fahrenheit (F) in 4 of 4 resident areas (North unit, South unit, West unit, and the guest-resident rest room). The findings were: 1. Observation on 6/21/17 at 12:59 PM of the guest-resident restroom by the dining rooms showed the hot water temperature at the sink measured 114.6 degrees F. 2. Observation of the North unit on 6/22/17 showed the following: a. At 9:54 AM the temperature of the	S2924	S2924 The facility shall ensure hot water temperatures in resident bathrooms and showers do not exceed 110 degrees Fahrenheit A. The mixing valve was adjusted immediately upon notification of this finding and will be adjusted as needed to keep the temperatures below 110 degrees. Weekly audits will be completed to ensure temperatures are being kept under 110 degrees Fahrenheit. B. All residents, visitor, and staff members have the potential to be affected by failure to ensure hot water temperatures in bathrooms and showers do not exceed 110 Fahrenheit.	

Wyoming Dept of Health, Aging Division, Healthcare Licensing and Surveys
LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

STATE FORM

6899

BK9V11

If continuation sheet 1 of 2

RECEIVED JUL 20 2017 Healthcare Licensing and Surveys

Accepted 8-26-17
Talked with
Jason Gedney
on 7-26-17 @ 11:15 AM
Doc 8-6-17
[Signature]

Healthcare Licensing and Surveys

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: WY0024	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 06/22/2017
NAME OF PROVIDER OR SUPPLIER POWELL VALLEY CARE CENTER		STREET ADDRESS, CITY, STATE, ZIP CODE 777 AVENUE H POWELL, WY 82435		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
S2924	Continued From page 1 bathroom sink hot water in room 409 measured 121.3 degrees F. b. At 9:57 AM the temperature of the bathroom sink hot water in room 412 measured 118.3 degrees F. c. At 9:59 AM the temperature of the bathroom sink hot water in room 405 measured 111.8 degrees F. d. At 10:01 AM the temperature of the bathroom sink hot water in room 401 measured 103.9 degrees F. 3. Observation of the South unit on 6/22/17 showed the following: a. At 9:08 AM the temperature of the bathroom sink hot water in room 112 measured 112.3 degrees F. b. At 9:16 AM the temperature of the bathroom sink hot water in room 102 measured 112.8 degrees F. 4. Observation of the West unit on 6/22/17 at 9:21 AM showed the following: a. The hot water was measured to be 112.8 degrees F in room 217 and 114.3 degrees F in room 309. 5. Review of the facility's domestic hot water temperature log showed the temperatures fluctuated from 103.5 degrees F to 120.4 degrees over the months of April through June 2017. 6. Interview with the administrator on 6/22/17 at 9:37 AM revealed she was unaware the temperatures were too high. She stated the temperatures were being monitored and reported to the quality committee with an average temperature of 109 degrees F.	S2924	C. Education will be provided to all Plant Operations staff regarding the need to ensure hot water temperatures in bathrooms and showers do not exceed 110 degrees Fahrenheit and to take immediate corrective action to prevent risk or actual from burning if the temperature is beyond 110 degrees. The Facilities Management Director or designee will perform audits weekly to ensure the temperatures do not exceed 110 degrees Fahrenheit and maintain documentation of corrective action taken at the time a temperature exceeds 110 degrees Fahrenheit if applicable. D. The Facilities Management Director will aggregate monthly data and report results to the Administrator, Care Center Medical Director, and Quality Council quarterly. Quality Council will have the overall responsibility to ensure the facility is in compliance. Completion Date	08/6/2017

Accepted 7.26.17
[Signature]