

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES


PRINTED: 07/25/2017
FORM APPROVED
OMB NO. 0938-0391


STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 535040	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 07/17/2017
NAME OF PROVIDER OR SUPPLIER DOUGLAS CARE CENTER LLC			STREET ADDRESS, CITY, STATE, ZIP CODE 1108 BIRCH STREET DOUGLAS, WY 82633		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
K 000	INITIAL COMMENTS A Life Safety Code survey was conducted by Healthcare Licensing and Surveys on 7/17/2017. Requirements for Long Term Care Facilities Section 42 CFR 483.70(a) except as otherwise provided in the section, the facility must meet the applicable provisions of the 2012 Edition of the Life Safety Code, Existing Health Care, of the National Fire Protection Association. The facility was a partially sprinklered single story building with a basement of Type V (111) construction built in 1987 and 2010. The building was equipped with a supervised wet sprinkler system with a dry branch, and an addressable fire alarm system. The facility had a capacity of 60 certified Medicare and Medicaid beds with a census of 57 residents.	K 000			
K 351 SS=D	NFPA 101 Sprinkler System - Installation Spinkler System - Installation 2012 EXISTING Nursing homes, and hospitals where required by construction type, are protected throughout by an approved automatic sprinkler system in accordance with NFPA 13, Standard for the Installation of Sprinkler Systems. In Type I and II construction, alternative protection measures are permitted to be substituted for sprinkler protection in specific areas where state or local regulations prohibit sprinklers. In hospitals, sprinklers are not required in clothes closets of patient sleeping rooms where the area of the closet does not exceed 6 square feet and sprinkler coverage covers the closet footprint as required by NFPA 13, Standard for Installation of Sprinkler Systems.	K 351			


LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE







Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

AUG 09 2017

ACCEPTED POL VIA PHONE CALL WITH ADMINISTRATOR KELLY ROGGE


FORM CMS-2567(02-99) Previous Versions Obsolete

Event ID: JPN821

Facility ID: WY0016

8-30-2017 If continuation sheet Page 1 of 4

Healthcare Licensing and Surveys



DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 07/25/2017
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 535040	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 07/17/2017
NAME OF PROVIDER OR SUPPLIER DOUGLAS CARE CENTER LLC			STREET ADDRESS, CITY, STATE, ZIP CODE 1108 BIRCH STREET DOUGLAS, WY 82633		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
K 351	Continued From page 1 19.3.5.1, 19.3.5.2, 19.3.5.3, 19.3.5.4, 19.3.5.5, 19.4.2, 19.3.5.10, 9.7, 9.7.1.1(1) This STANDARD is not met as evidenced by: Based on observation and staff interview, the facility failed to protect the building throughout by an approved, automatic sprinkler system in accordance with 2012 NFPA 101, Life Safety Code, 2010 NFPA 13, Installation of Sprinkler Systems, and SNC Letter 13-55. The findings were: Observation on 7/18/2017 at 11:05 AM in rooms 302, 308 and 309 revealed built-in closets that included a bar for hanging clothing, and that the top of the closet enclosure was continuous to the ceiling of the room. Further observation revealed that there were no sprinklers provided within the closets. Failure to provide sprinkler systems as required could result in injury or death during an emergency. Interview with the Facility Administrator and Facility Maintenance Manager at the time of observation indicated they were aware of the requirement, and they had purchased new wardrobes for room 308. REF: 2012 NFPA 101, Sections 19.3.5.1: 9.7.1.1 2010 NFPA 13, Section 1-6.1 SNC Letter 13-55	K 351	<u>K351</u> a) The facility will ensure closets will be removed and replaced with removable armoires for rooms 302, 308 and 309. b) NHA or designee will educate Maintenance on the importance of removable closets. c) Maintenance or designee will monitor for one month or until resolved and results will be brought to QAPI.		08/20/17
K 741 SS=E	NFPA 101 Smoking Regulations Smoking Regulations Smoking regulations shall be adopted and shall include not less than the following provisions: (1) Smoking shall be prohibited in any room, ward, or compartment where flammable liquids, combustible gases, or oxygen is used or stored and in any other hazardous location, and such area shall be posted with signs that read NO	K 741			

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 07/25/2017
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 535040	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 07/17/2017
NAME OF PROVIDER OR SUPPLIER DOUGLAS CARE CENTER LLC			STREET ADDRESS, CITY, STATE, ZIP CODE 1108 BIRCH STREET DOUGLAS, WY 82633		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
K 741	Continued From page 2 SMOKING or shall be posted with the international symbol for no smoking. (2) In health care occupancies where smoking is prohibited and signs are prominently placed at all major entrances, secondary signs with language that prohibits smoking shall not be required. (3) Smoking by patients classified as not responsible shall be prohibited. (4) The requirement of 18.7.4(3) shall not apply where the patient is under direct supervision. (5) Ashtrays of noncombustible material and safe design shall be provided in all areas where smoking is permitted. (6) Metal containers with self-closing cover devices into which ashtrays can be emptied shall be readily available to all areas where smoking is permitted. 18.7.4, 19.7.4 This STANDARD is not met as evidenced by: Based on observation and staff interview, the facility failed to maintain smoking regulations in accordance with the 2012 NFPA 101, Life Safety Code. The findings were: Observation on 7/18/2017 at 9:30 AM at the main entrance revealed that the facility did not post a No Smoking sign despite being a no smoking facility. No Smoking signs need to be posted at all main entrances to the facility to insure residents safety. Further observation revealed that the facility did not provide secondary signs with the language that prohibits smoking or the international symbol for no smoking. Failure to comply with smoking regulations as required could result in injury or death. Interview with the Facility Administrator and Facility Maintenance Manager at the time of observation indicated they were aware of the requirement.	K 741	<u>K741</u> a) No Smoking signs will be hung at all main entrances to the facility to insure residents' safety. b) NHA or designee will educate Maintenance on the importance of hanging no smoking signs at all main entrances. c) Maintenance or designee will monitor for one month or until resolved. Results will be brought to QAPI.	08/20/17	

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 07/25/2017
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 535040	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 07/17/2017
NAME OF PROVIDER OR SUPPLIER DOUGLAS CARE CENTER LLC			STREET ADDRESS, CITY, STATE, ZIP CODE 1108 BIRCH STREET DOUGLAS, WY 82633		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
K 741	Continued From page 3 REF: 2012 NFPA 101, Section 19.7.4	K 741			