

Healthcare Licensing and Surveys

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: WY0014	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 01/27/2022
NAME OF PROVIDER OR SUPPLIER LIFE CARE CENTER OF CHEYENNE		STREET ADDRESS, CITY, STATE, ZIP CODE 1330 PRAIRIE AVENUE CHEYENNE, WY 82009		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
S 000	General Comments A Life Safety Code survey was conducted by Healthcare Licensing and Surveys on January 27, 2022. Wyoming Department of Health, Rules and Regulations for Licensure of Nursing Care Facilities Chapter 19, Section 8 Life Safety and Electrical Safety. The requirements in the Department of Health Chapter III, Construction Rules and Regulations for Health Care Facilities apply. The facility was a fully sprinklered one story building of Type V (111) construction with plan approval in 1987 and 2009. The building was equipped with a supervised wet sprinkler system with a dry sprinkler branch, and an addressable fire alarm system. The facility had 160 certified Medicare and Medicaid beds with a census of 100 residents.	S 000		
S7036	IPC Life Safety - Int'l Plumbing Code This State Rule and Regulation is not met as evidenced by: Based on observation and staff interview, the facility failed to provide an eyewash station with adequate pressure and water flow in accordance with the International Plumbing Code and ANSI Z358.1. The failure to provide adequate pressure and water flow to emergency fixtures could result in inadequate performance of the fixture, resulting in eye damage during an emergency. The deficiency was present at one (1) of several eyewash stations in the facility. The findings were: Observation on 1/27/2022 at 9:59 AM at the	S7036	S7036 1. On 1/28/2022, maintenance department repaired the mixing valve which was stuck. It was observed to provide adequate water pressure to be put back into service 1/28/2022 @ 1:00 pm. It will be monitored by maintenance staff and logged in T.E.L's.	1/28/22

Wyoming Dept of Health, Aging Division, Healthcare Licensing and Surveys
LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Electronically Signed

02/18/22

Healthcare Licensing and Surveys

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: WY0014	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 01/27/2022
NAME OF PROVIDER OR SUPPLIER LIFE CARE CENTER OF CHEYENNE		STREET ADDRESS, CITY, STATE, ZIP CODE 1330 PRAIRIE AVENUE CHEYENNE, WY 82009		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
S7036	Continued From page 1 eyewash station in the soiled utility room in the SRU West revealed inadequate pressure, resulting in low water flow, which was incapable of exiting the discharge of the fixture for appropriate use. Interview with the safety director at the time of observation acknowledged the deficiency, and indicated awareness of the requirement. Interview with the facility administrator at the time of exit acknowledged the deficiency. REF: 2006 International Plumbing Code Section 411.1, ANSI-Z358.1 5.1.6	S7036		