

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 08/27/2024
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 535053	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 07/25/2024
NAME OF PROVIDER OR SUPPLIER PLATTE COUNTY LEGACY HOME			STREET ADDRESS, CITY, STATE, ZIP CODE 100 19TH ST WHEATLAND, WY 82201		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
E 000	Initial Comments An Emergency Preparedness Survey was conducted by Healthcare Licensing and Surveys on 07/05/2024. Based upon the findings of the survey, it was determined the facility was in compliance with all requirements of 42 CFR 483.73.	E 000			
K 000	INITIAL COMMENTS A Life Safety Code survey was conducted by Healthcare Licensing and Surveys on 07/25/2024. Requirements for Long Term Care Facilities Section 42 CFR 483.90, except as otherwise provided in the section, the facility must meet the applicable provisions of the 2012 Edition of the Life Safety Code, Existing Health Care of the National Fire Protection Association.	K 000			
K 900 SS=D	The facility was a fully sprinklered, single story building of Type V (111) with plan approval in 2014. The building was equipped with a supervised automatic wet and dry sprinkler system, and an addressable fire alarm system. The facility had a capacity of 50 certified Medicare and Medicaid beds with a census of 44 residents. The findings that follow demonstrate noncompliance with 42 CFR 483.90. Health Care Facilities Code - Other CFR(s): NFPA 101 Health Care Facilities Code - Other List in the REMARKS section any NFPA 99 requirements (excluding Chapter 7, 8, 12, and 13) that are not addressed by the provided K-Tags, but are deficient. This information, along with the applicable Health Care Facilities Code or NFPA standard citation, should be included on Form CMS-2567.	K 900			8/19/24

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Electronically Signed

08/16/2024

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 08/27/2024
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 535053	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 07/25/2024
NAME OF PROVIDER OR SUPPLIER PLATTE COUNTY LEGACY HOME			STREET ADDRESS, CITY, STATE, ZIP CODE 100 19TH ST WHEATLAND, WY 82201		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 900	Continued From page 1 This REQUIREMENT is not met as evidenced by: Based on document review and staff interview, the facility failed to maintain main and feeder circuit breakers in accordance with 2012 NFPA 99, Heath Care Facilities Code. Failure to maintain main and feeder circuit breakers as required could result in faulty or inoperable equipment. The deficiency affected the facilities essential electrical system. The findings were: Document review on 07/25/2024 starting at 10:45 AM revealed the facility was not able to provide documentation demonstrating that the main and feeder circuit breakers had been tested. Main and feeder circuit breakers shall be inspected annually, and a program for periodically exercising the components shall be established according to manufacturer's recommendations. Interview with the maintenance manager at the time of observation confirmed the deficiency, and indicated that he was aware of the requirement. Interview with the administrator at the time of exit confirmed the deficiency. Ref: 2012 NFPA 99 Ch.10 Sec. 4.4.1.2	K 900	K900 Corrective action: The Environmental Manager will actuate the breaker no later than August 19th, 2024. And take immediate corrective action if needed. Systemic changes: The Environmental Manager will follow the Siemens feeder circuit breaker manufacturer's recommendation of inspection, which is actuating the breaker once yearly by a visual inspection of the breaker in accordance with NEMA AB4. The Monitoring: Environmental Manager will add these annual inspections to the TELS program. And keep an annual log of actuating the breaker.		