

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICESPRINTED: 09/03/2008
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 535030	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - NEW HORIZONS CARE C B. WING _____		(X3) DATE SURVEY COMPLETED 08/19/2008
NAME OF PROVIDER OR SUPPLIER NEW HORIZONS CARE CENTER			STREET ADDRESS, CITY, STATE, ZIP CODE 1115 LANE 12 LOVELL, WY 82431		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 000	INITIAL COMMENTS Requirements for Long Term Care Facilities Section 42 CFR 483.70 (a) except as otherwise provided in the section, the facility must meet the applicable provisions of the 200 edition of the Life Safety Code, Existing Health Care, of the National Fire Protection Association (NFPA). The facility was a fully sprinkled two story building of Type II (111) construction built in 1991. The building was equipped with an supervised automatic wet sprinkler system and addressable fire alarm system. The facility meets the Life Safety Code standard based on the acceptance of a plan of correction and an Fire Safety and Evaluation System (FSES). Tag K-017 can be obviated by the Fire Safety and Evaluation System (FSES). If the facility agrees to the conditions of the FSES they can write and "F" in the providers Plan of Correction column and Complete Date column to accept the FSES. If the facility wants to fix the deficiency they can fill in the Providers Plan of Correction column with the appropriate information and dates.	K 000	<i>POC accepted w/ FSES</i> <i>Explan 12, 13, 14, 15, 16, 17, 18, 19, 20, 21, 22, 23, 24, 25, 26, 27, 28, 29, 30, 31, 32, 33, 34, 35, 36, 37, 38, 39, 40, 41, 42, 43, 44, 45, 46, 47, 48, 49, 50, 51, 52, 53, 54, 55, 56, 57, 58, 59, 60, 61, 62, 63, 64, 65, 66, 67, 68, 69, 70, 71, 72, 73, 74, 75, 76, 77, 78, 79, 80, 81, 82, 83, 84, 85, 86, 87, 88, 89, 90, 91, 92, 93, 94, 95, 96, 97, 98, 99, 100, 101, 102, 103, 104, 105, 106, 107, 108, 109, 110, 111, 112, 113, 114, 115, 116, 117, 118, 119, 120, 121, 122, 123, 124, 125, 126, 127, 128, 129, 130, 131, 132, 133, 134, 135, 136, 137, 138, 139, 140, 141, 142, 143, 144, 145, 146, 147, 148, 149, 150, 151, 152, 153, 154, 155, 156, 157, 158, 159, 160, 161, 162, 163, 164, 165, 166, 167, 168, 169, 170, 171, 172, 173, 174, 175, 176, 177, 178, 179, 180, 181, 182, 183, 184, 185, 186, 187, 188, 189, 190, 191, 192, 193, 194, 195, 196, 197, 198, 199, 200, 201, 202, 203, 204, 205, 206, 207, 208, 209, 210, 211, 212, 213, 214, 215, 216, 217, 218, 219, 220, 221, 222, 223, 224, 225, 226, 227, 228, 229, 230, 231, 232, 233, 234, 235, 236, 237, 238, 239, 240, 241, 242, 243, 244, 245, 246, 247, 248, 249, 250, 251, 252, 253, 254, 255, 256, 257, 258, 259, 260, 261, 262, 263, 264, 265, 266, 267, 268, 269, 270, 271, 272, 273, 274, 275, 276, 277, 278, 279, 280, 281, 282, 283, 284, 285, 286, 287, 288, 289, 290, 291, 292, 293, 294, 295, 296, 297, 298, 299, 300, 301, 302, 303, 304, 305, 306, 307, 308, 309, 310, 311, 312, 313, 314, 315, 316, 317, 318, 319, 320, 321, 322, 323, 324, 325, 326, 327, 328, 329, 330, 331, 332, 333, 334, 335, 336, 337, 338, 339, 340, 341, 342, 343, 344, 345, 346, 347, 348, 349, 350, 351, 352, 353, 354, 355, 356, 357, 358, 359, 360, 361, 362, 363, 364, 365, 366, 367, 368, 369, 370, 371, 372, 373, 374, 375, 376, 377, 378, 379, 380, 381, 382, 383, 384, 385, 386, 387, 388, 389, 390, 391, 392, 393, 394, 395, 396, 397, 398, 399, 400, 401, 402, 403, 404, 405, 406, 407, 408, 409, 410, 411, 412, 413, 414, 415, 416, 417, 418, 419, 420, 421, 422, 423, 424, 425, 426, 427, 428, 429, 430, 431, 432, 433, 434, 435, 436, 437, 438, 439, 440, 441, 442, 443, 444, 445, 446, 447, 448, 449, 450, 451, 452, 453, 454, 455, 456, 457, 458, 459, 460, 461, 462, 463, 464, 465, 466, 467, 468, 469, 470, 471, 472, 473, 474, 475, 476, 477, 478, 479, 480, 481, 482, 483, 484, 485, 486, 487, 488, 489, 490, 491, 492, 493, 494, 495, 496, 497, 498, 499, 500, 501, 502, 503, 504, 505, 506, 507, 508, 509, 510, 511, 512, 513, 514, 515, 516, 517, 518, 519, 520, 521, 522, 523, 524, 525, 526, 527, 528, 529, 530, 531, 532, 533, 534, 535, 536, 537, 538, 539, 540, 541, 542, 543, 544, 545, 546, 547, 548, 549, 550, 551, 552, 553, 554, 555, 556, 557, 558, 559, 560, 561, 562, 563, 564, 565, 566, 567, 568, 569, 570, 571, 572, 573, 574, 575, 576, 577, 578, 579, 580, 581, 582, 583, 584, 585, 586, 587, 588, 589, 590, 591, 592, 593, 594, 595, 596, 597, 598, 599, 600, 601, 602, 603, 604, 605, 606, 607, 608, 609, 610, 611, 612, 613, 614, 615, 616, 617, 618, 619, 620, 621, 622, 623, 624, 625, 626, 627, 628, 629, 630, 631, 632, 633, 634, 635, 636, 637, 638, 639, 640, 641, 642, 643, 644, 645, 646, 647, 648, 649, 650, 651, 652, 653, 654, 655, 656, 657, 658, 659, 660, 661, 662, 663, 664, 665, 666, 667, 668, 669, 670, 671, 672, 673, 674, 675, 676, 677, 678, 679, 680, 681, 682, 683, 684, 685, 686, 687, 688, 689, 690, 691, 692, 693, 694, 695, 696, 697, 698, 699, 700, 701, 702, 703, 704, 705, 706, 707, 708, 709, 710, 711, 712, 713, 714, 715, 716, 717, 718, 719, 720, 721, 722, 723, 724, 725, 726, 727, 728, 729, 730, 731, 732, 733, 734, 735, 736, 737, 738, 739, 740, 741, 742, 743, 744, 745, 746, 747, 748, 749, 750, 751, 752, 753, 754, 755, 756, 757, 758, 759, 760, 761, 762, 763, 764, 765, 766, 767, 768, 769, 770, 771, 772, 773, 774, 775, 776, 777, 778, 779, 780, 781, 782, 783, 784, 785, 786, 787, 788, 789, 790, 791, 792, 793, 794, 795, 796, 797, 798, 799, 800, 801, 802, 803, 804, 805, 806, 807, 808, 809, 810, 811, 812, 813, 814, 815, 816, 817, 818, 819, 820, 821, 822, 823, 824, 825, 826, 827, 828, 829, 830, 831, 832, 833, 834, 835, 836, 837, 838, 839, 840, 841, 842, 843, 844, 845, 846, 847, 848, 849, 850, 851, 852, 853, 854, 855, 856, 857, 858, 859, 860, 861, 862, 863, 864, 865, 866, 867, 868, 869, 870, 871, 872, 873, 874, 875, 876, 877, 878, 879, 880, 881, 882, 883, 884, 885, 886, 887, 888, 889, 890, 891, 892, 893, 894, 895, 896, 897, 898, 899, 900, 901, 902, 903, 904, 905, 906, 907, 908, 909, 910, 911, 912, 913, 914, 915, 916, 917, 918, 919, 920, 921, 922, 923, 924, 925, 926, 927, 928, 929, 930, 931, 932, 933, 934, 935, 936, 937, 938, 939, 940, 941, 942, 943, 944, 945, 946, 947, 948, 949, 950, 951, 952, 953, 954, 955, 956, 957, 958, 959, 960, 961, 962, 963, 964, 965, 966, 967, 968, 969, 970, 971, 972, 973, 974, 975, 976, 977, 978, 979, 980, 981, 982, 983, 984, 985, 986, 987, 988, 989, 990, 991, 992, 993, 994, 995, 996, 997, 998, 999, 1000</i>		
K 012 SS=D	NFPA 101 LIFE SAFETY CODE STANDARD Building construction type and height meets one of the following. 19.1.6.2, 19.1.6.3, 19.1.6.4, 19.3.5.1 This STANDARD is not met as evidenced by: Based on observation and staff interview the facility failed to ensure resident room walls were	K 012	A) Wall fire and smoke resistance will be maintained for the safety of residents. B) Wall penetrations will be repaired with type x wallboard and fire taped. C) Resident wall inspection will be added to housekeeping room checklist. <i>updated daily</i>	09-15-08	

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Chief Executive Officer 9-9-08

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 09/03/2008
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 535030	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - NEW HORIZONS CARE CI B. WING _____		(X3) DATE SURVEY COMPLETED 08/19/2008
NAME OF PROVIDER OR SUPPLIER NEW HORIZONS CARE CENTER			STREET ADDRESS, CITY, STATE, ZIP CODE 1115 LANE 12 LOVELL, WY 82431		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 017	Continued From page 2 1. Observation on 8/19/08 between 8:30 AM and 12:30 PM revealed the first and second floor corridor walls terminated above the lay in ceiling tiles. The open space above the corridors and resident rooms were used as an air plenum for the ventilation system. 2. Interview with the maintenance director on 8/19/08 at 12:30 PM confirmed the ventilation system was not ducted and the open plenum was used to transfer air. This deficiency can be obviated by the Fire Safety and Evaluation System (FSES). If the facility agrees to the conditions of the FSES they can write and "F" in the Provider's Plan of Correction column and Complete Date column to accept the FSES. If the facility wants to fix the deficiency they can fill in the Provider's Plan of Correction column with the appropriate information and dates.	K 017			
K 062 SS=E	NFPA 101 LIFE SAFETY CODE STANDARD Required automatic sprinkler systems are continuously maintained in reliable operating condition and are inspected and tested periodically. 19.7.6, 4.6.12, NFPA 13, NFPA 25, 9.7.5 This STANDARD is not met as evidenced by: Based on observation and staff interview the facility failed to ensure sprinkler heads were free of foreign material in one of six smoke compartments. The findings were: Observation on 8/19/08 at 12:30 PM revealed the sprinkler head in the corridor near resident room	K 062	A) The automatic sprinkler system will be maintained in reliable operating condition for the safety of residents and staff. B) Faulty spinkler will be replaced with a new sprinkler. C) A visual inspection of the sprinkler system will be conducted quarterly and documented on the preventative maintenance checklist. D) These checklists will be monitored by the Facility Services Director for completion. E) Results of these checklists will be reported at quarterly Quality Assurance meetings.	9-8-08	

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 09/03/2008
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 535030	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - NEW HORIZONS CARE CI B. WING _____		(X3) DATE SURVEY COMPLETED 08/19/2008
NAME OF PROVIDER OR SUPPLIER NEW HORIZONS CARE CENTER			STREET ADDRESS, CITY, STATE, ZIP CODE 1116 LANE 12 LOVELL, WY 82431		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
K 062	Continued From page 3	K 062			
K 074 SS=E	#210 had been painted, Interview with the maintenance director at the time of observation revealed the sprinkler system was inspected annually for damaged or painted heads. NFPA 101 LIFE SAFETY CODE STANDARD Draperies, curtains, including cubicle curtains, and other loosely hanging fabrics and films serving as furnishings or decorations in health care occupancies are in accordance with provisions of 10.3.1 and NFPA 13, Standards for the Installation of Sprinkler Systems. Shower curtains are in accordance with NFPA 701. Newly introduced upholstered furniture within health care occupancies meets the criteria specified when tested in accordance with the methods cited in 10.3.2 (2) and 10.3.3, 19.7.5.1, NFPA 13 Newly introduced mattresses meet the criteria specified when tested in accordance with the method cited in 10.3.2 (3), 10.3.4, 19.7.5.3 This STANDARD is not met as evidenced by: Based on observation, record review and staff interview the facility failed to ensure window curtains were flame retardant in two of six smoke compartments. The findings were: 1. Observation on 8/19/08 between 10:30 AM and 11:30 AM revealed the following locations had window curtains without flame retardant documentation:	K 074	A) Flame retardent requirements of NFPA 13 for window curtains will be maintained for the safety of residents. B) Window curtains will be treated with fabric seal fire retardent. C) Housekeeping will label all treated curtains with date treated. Any curtains removed for cleaning will be retreated and dated by housekeeping. D) Housekeeping will forward a log of treated curtains to the Facility Services Director. E) This log will be reviewed quarterly by the Facility Services Director to insure compliance and forwarded to the Quality Assurance Committee.	9/15/08	

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 09/03/2008
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 535030	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - NEW HORIZONS CARE CI B. WING _____		(X3) DATE SURVEY COMPLETED 08/19/2008
NAME OF PROVIDER OR SUPPLIER NEW HORIZONS CARE CENTER			STREET ADDRESS, CITY, STATE, ZIP CODE 1115 LANE 12 LOVELL, WY 82431		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 074	Continued From page 4 a. Resident room #207. b. Resident room #320. c. Resident room #322. 2. Review of the applied flame retardant spray log revealed none of the above mentioned rooms were in the log. 3. Interview with the maintenance director on 8/19/08 at 2:30 PM revealed all curtains were inspected quarterly by the housekeeping staff to ensure they were flame retardant.	K 074			
K 147 SS-D	NFPA 101 LIFE SAFETY CODE STANDARD Electrical wiring and equipment is in accordance with NFPA 70, National Electrical Code. 9.1.2 This STANDARD is not met as evidenced by: Based on observation and staff interview the facility failed to ensure electrical cords were not pinched in one of six smoke compartments. The findings were: Observation on 8/19/08 at 8:52 AM revealed the electrical cord to the DVD player in resident room 3227 was pinched by the door of the television cabinet. Interview with the maintenance director at the time of observation revealed the electrical system was inspected monthly.	K 147	A) Electrical wiring will be maintained in compliance of NFPA 70 for the safety of residents. B) Electrical cord was relocated through the back of the cabinet to prevent pinching by the door. C) Inspection for electrical cord damage or possible damage will be added to the maintenance monthly preventative maintenance schedule. D) Preventative maintenance checklists will be monitored by the Facility Services Director. E) Results of these checklists will be reported to the Quality Assurance Committee.	9-8-08	